

**CENTRAL ASIA NATURAL RESOURCES MANAGEMENT PROGRAM
TRANSBOUNDARY WATER AND ENERGY PROJECT**

**AN ASSESSMENT OF KAMBARATA 1 AND 2 HYDROPOWER
PROJECTS**

Contract No. LAG I-00-99-00019

Order No: 809

Funded by:

U.S. Agency for International Development
Regional Mission for Central Asia
Office of Energy and Water
Park Palace Building
41 Kazybek bi Street
Almaty, Kazakhstan 480091
(7-3272) 50-76-17

Prepared by:

PA Consulting Group
119 Ahunbaeva Street
Bishkek, Kyrgyzstan 720055
(996-312) 54-85-52

and

PA Government Services
1750 Pennsylvania Avenue NW
Suite 1000
Washington DC 20006-4506
(202) 442-2000

March 12, 2003

The reproduction or distribution for sale of any portion of this report without the express written consent of PA Consulting is prohibited. Any other reproduction, publication, distribution, or use of the material contained herein must include this acknowledgement and prohibition.

TABLE OF CONTENTS

GLOSSARY	I
SUMMARY AND CONCLUSIONS	1
1. INTRODUCTION	3
1.1 USAID SUPPORT TO THE WATER AND ENERGY SECTOR OF THE CAR	3
1.2 SCOPE OF THIS REPORT	4
2. THE POWER SYSTEM OF THE CENTRAL ASIAN REPUBLICS	5
2.1 THE PRESENT SITUATION	5
2.2 INTEGRATED OPERATION: POTENTIALS AND PROBLEMS	6
3. THE KYRGYZSTAN POWER SYSTEM	8
3.1 THE PRESENT SITUATION	8
3.2 POWER OPERATIONS IN RELATION TO WATER MANAGEMENT	8
3.3 LOAD FORECAST	10
3.4 ALTERNATIVE TOKTOGUL OPERATING REGIMES	11
4. THE KAMBARATA 1 AND 2 PROJECTS	14
4.1 EXISTING STUDIES AND DATA	14
4.2 DAM ALTERNATIVES CONSIDERED	14
5. COST ESTIMATES	16
5.1 KAMBARATA 1	16
5.2 KAMBARATA 2	16
6. BENEFITS TO THE CAR AND KYRGYZSTAN ENERGY SYSTEMS	18
6.1 RESULTS OF SYSTEM OPERATION STUDIES	18
6.2 CONTRIBUTION TO THE KYRGYZSTAN ENERGY SYSTEM	19
6.3 CONTRIBUTION TO THE CENTRAL ASIAN POWER SYSTEM	20
7. ECONOMIC FEASIBILITY	22
7.1 METHOD OF ANALYSIS	22
7.2 KAMBARATA 1	22
7.3 KAMBARATA 2	23
8. WATER MANAGEMENT, SOCIAL, AND ENVIRONMENTAL IMPACTS	24
9. NEXT STEPS	25

TABLES

TABLE 1.1	MEASURES TO IMPROVE REGIONAL WATER AND ENERGY COOPERATION.....	3
TABLE 2.1	CENTRAL ASIAN REPUBLICS: POWER PLANTS AND TRANSMISSION LINES	5
TABLE 3.1	DEMAND BY CONSUMER GROUP	10
TABLE 3.2	COMPARISON OF TOKTOGUL OPERATING REGIMES	12
TABLE 6.1	COMPARISON OF ALTERNATIVES FOR THE YEAR 2015	19

ANNEXES

ANNEX A	KYRGYZSTAN GENERATION, EXPORTS, AND IMPORTS: 1999-2001.....	26
ANNEX B	LOAD FORECAST: KYRGYZSTAN	29
ANNEX C	BASIC DATA	30
ANNEX D	TOKTOGUL OPERATING REGIMES.....	31
ANNEX E	SYSTEM OPERATION STUDIES.....	34
ANNEX F	COST ESTIMATES.....	43

FIGURES

FIGURE 1	ARAL SEA BASIN	45
FIGURE 2	THE CAPS GRID	46
FIGURE 3	WATER AND HYDROPOWER FACILITIES OF THE SYR DARYA BASIN.....	47
FIGURE 4	THE NARYN CASCADE.....	48
FIGURE 5	KAMBARATA 1 - GENERAL ARRANGEMENT	49
FIGURE 6	KAMBARATA 1 – SECTIONS.....	50
FIGURE 7	KAMBARATA 2 - GENERAL ARRANGEMENT	51
FIGURE 8	KAMBARATA 2 - SECTIONS	52

GLOSSARY

ABBREVIATIONS

ADB	Asian Development Bank
CAPS	Central Asian Power System
CAR	Central Asian Republics
CHP	Combined Heat and Power Plant
EDR	Equalizing discount rate
ERR	Economic rate of return
HPP	Hydro Power Plant
ICWC	Interstate Commission for Water Coordination
IFI	International Financial Institution
JSC	Joint Stock Company
LS	Lump Sum
MUV Index	Index of the Value of Manufactured Export
NRMP	Natural Resources Management Program
PCCAR	Power Council of Central Asia Republics
SEA	State Energy Agency
TO	Task Order
TPP	Thermal Power Plant
TWEP	Transboundary Water and Energy Project
UDC	Unified Dispatch Center
UPSCAR	United Power System of Central Asia Republics
USAID	United States Agency for International Development
USAID/CAR	USAID Mission for Central Asia
WB	World Bank

CURRENCY EQUIVALENTS

US\$ 1 = 46,2 som (as of November, 2002)

WEIGHTS AND MEASURERS

kWh = Kilowatt hour (= 860.42 kcals)
GWh = Gigawatt hour (one million kilowatt hours)
kW = Kilowatt (1,000 watts)
MW = Megawatt (1,000 kilowatts)
kV = Kilovolt (1,000 volts)
mcm = One million cubic meters
bcm = One billion cubic meters (One cubic kilometer)

EQUATIONS

1 mcm of water under 1 meter of head = 2,724 kWh at 100% efficiency
1 cubic meter per second of water under meter of head = 9.81 kW at 100% efficiency

System Load Factor = Average Demand /Peak Demand for a given period of time.
Example: January 2000 energy demand for Kyrgyzstan = 1,606 GWh and January peak demand is 2,604 MW: the load factor is $(1,606,000/744)/2,604,000 = 84\%$

Plant factor = Average Output/Peak Output of a power plant for a given period of time.
Example: If Kambarata 1 produces 398 GWh in September and can operate at 1,200 MW (reservoir full): the plant factor is $(398/.720)/1,200 = 46\%$

SUMMARY AND CONCLUSIONS

The Kambarata 1 Hydropower Project at a cost of about US\$ 1.2 billion, an installed capacity of 1,200 MW and annual energy generation of 4,500 GWh would be competitive with a thermal power project in the future expansion of Kyrgyzstan's power system. Although Kambarata 1 has a higher initial capital cost than the thermal alternative, the avoided annual cost of fuel imports would be around US\$100 million. The installed capacity could be increased to 1,600 MW, and even higher, to provide peaking capacity for the Central Asian Power System (CAPS).

The Kambarata 2 Hydropower Project at a cost of about US\$ 280 million, an installed capacity of 400 MW and annual energy generation of 1,260 GWh could be a low-cost source of peaking power for export to South Kazakhstan or Uzbekistan as a part of the CAPS and increase Kyrgyzstan's summer hydro energy surplus.

Further study of the two projects is justified to refine designs and cost estimates, assess benefits in more detail, and to investigate possibilities for financing. Of particular interest would be a study of staged development of Kambarata 1 to bring the initial cost down to a level that might be more easily financed.

The basic problem with the Kyrgyzstan power system is that the hydropower projects of the Naryn Cascade (the 1,200 MW Toktogul dam and reservoir, and 1,670 MW of run-of-river hydropower plants), produce most of their energy in the summer, whereas the peak energy demand is in the winter months. The result is a high winter demand on the existing thermal power plants that requires large imports of fuel and energy. Consequently, the operators of Toktogul aim to maximize reservoir releases and energy production in the winter and minimize reservoir release to the downstream countries in the summer. To address this energy/irrigation conflict, the Syr Darya basin countries entered into the March 17, 1998 Framework Agreement between Kazakhstan, Kyrgyzstan and Uzbekistan on the Use of Water and Energy Resources of the Syr Darya Basin. Tajikistan became a party to this Agreement on June 19, 1998. This provides for winter fuel to be delivered to Kyrgyzstan in return for sales of hydro energy in the summer months.

This report looked at the effect on Kyrgyzstan's winter energy shortage of different operating regimes for the Toktogul Reservoir in the years before Kambarata 1 would be in service. It was found that none of the operating regimes, even the most extreme "power oriented regime", eliminates the need for large imports of fuel and energy under present conditions. By the Year 2005, with no additional capacity in service and average river flows, Kyrgyzstan will have an annual energy deficit of about 1,500 GWh, composed of a winter deficit of 3,900 GWh and a summer surplus of 2,400 GWh. The energy deficits have not reached these levels in the past because of unusually high reservoir inflows coupled with unsustainable withdrawals from the Toktogul Reservoir. Hydro energy generation has been 30% above sustainable levels. It is clear, therefore, that Kyrgyzstan's need for imports of fuel and energy will continue to grow until new capacity is installed.

The addition of Kambarata 1 would eliminate the winter deficits and thereby eliminate the conflict in the operation of the Toktogul Reservoir between the irrigation and environmental needs of the downstream countries and the winter energy needs of Kyrgyzstan. Kambarata 2

would add to Kyrgyzstan's summer hydro surplus that could be exchanged for fuel imports, but it would not significantly reduce the winter energy deficit.

Thus, the main elements of a power development plan for Kyrgyzstan should be:

- Rehabilitation of the existing thermal power plants at Bishkek and Osh to restore their capacity to 680 MW and 50 MW respectively.
- Continued imports of fuel and energy in return for exports of the summer hydro surplus under the 1998 Framework Agreement.
- Completion of the Kambarata 1 and Kambarata 2 Projects.
- An aggressive program to reduce losses from the present level of over 40% to no more than 18% (losses of 18% are assumed in the operation studies described in Chapter 6).
- A program to encourage consumers to move from electric heating to gas heating, and where possible coal heating.
- Investigation of Kyrgyzstan's coal resources as a base for thermal power (in the 1980's, over one million tons of coal was mined in the Kyrgyzstan, but production is now down to 100,000 tons).

The adverse social and environmental impacts of Kambarata 1 and Kambarata 2 appear to be quite limited. The reservoirs are reported to have no permanent residents and only a few livestock herdsman. Nevertheless, a detailed social and environmental assessment should be carried out.

A workshop was held in Bishkek on February 25-26, 2003 to seek the comments of Kyrgyzstan power sector officials on the report. This led to useful suggestions on technical issues and a valuable exchange of views on the regional aspects of the two projects. This report reflects the findings of the workshop.

Following discussions of the report with power sector officials in Kazakhstan, the next steps are likely to be as follows:

- Set up a Working Group of Kyrgyzstan and Kazakhstan experts to oversee the following activities.
- Prepare more detailed feasibility studies for the two projects. These would include an investigation of the possibility of staging Kambarata 1 including an analysis of different configurations of the 500 kV transmission network. The studies would present in more detail the costs and benefits of the projects and their contribution to the power systems of Kyrgyzstan and its neighbors, and their impact on water management.
- Investigate possible financing and institutional arrangements for further development of the projects.

1. INTRODUCTION

1.1 USAID Support to the Water and Energy Sector of the CAR

The strategy of the USAID Mission for Central Asia (USAID/CAR) is to support an improvement in the management of critical natural resources in the region through pilot projects to demonstrate good management and by training, public outreach and partnership development throughout the region. The strategy is being implemented by the Central Asia Natural Resource Management Program (NRMP).

The Transboundary Water and Energy Project (TWEP) under the NRMP supports activities that would help leaders in Central Asia develop and agree on measures to improve water and energy cooperation. TWEP focuses on the Syr Darya basin where a conflict has arisen between the energy needs of Kyrgyzstan and the irrigation needs of the downstream riparians. The Syr Darya basin is shared by Kyrgyzstan, Tajikistan, Uzbekistan and Kazakhstan (see Figure 1).

Table 1.1 gives an overview of the current status of measures that could help reduce seasonal conflicting demands in the use of water for power and irrigation in the Syr Darya basin. Measures that could be realized in the short term include energy loss reduction in Kyrgyzstan and better interstate agreements on water and energy use. In the medium term, projects in Tajikistan, Uzbekistan and Kazakhstan could be completed aimed at the seasonal re-regulation of water releases in the Syr Darya basin. Development of the Kambarata hydropower projects in Kyrgyzstan could improve water and energy cooperation in the long-term. The implementation of the listed “engineering” and “trading” measures need to be complemented by the strengthening of interstate institutions.

Table 1.1 Measures to improve regional water and energy cooperation.

Time Frame	Measures	Current Status
Short-term 0 - 2 years	Reduction of electricity losses in the Kyrgyz energy system	<ul style="list-style-type: none">• National loss reduction program defined• USAID and WB support its implementation
	Improvement of the implementation of the 1998 Framework Agreement	<ul style="list-style-type: none">• USAID supports the development of the additional information required for meaningful discussions on the issue
	Improvement of coordination between water and energy dispatchers	<ul style="list-style-type: none">• USAID supports needs assessment• Possible follow-up by USAID and ADB
	Agreement on Power Trade Relations	<ul style="list-style-type: none">• USAID supports the development of the agreement under the proposed Regional Power Transmission Modernization Project, supported by loans from the ADB and EBRD
Medium-	Improvement of Chardara Reservoir (Kazakhstan)	<ul style="list-style-type: none">• Implemented under the SYNAS project supported by a WB loan

term 3 – 7 years	Improvement of carrying capacity Syr Darya downstream of Chardara	<ul style="list-style-type: none"> Implemented under the SYNAS project
	Improvement of Kairakum Reservoir and surrounding irrigated areas (Tajikistan)	<ul style="list-style-type: none"> Tajikistan, Uzbekistan, and Kazakhstan signed protocol to undertake feasibility study USAID and WB support project preparation
	Strengthening of interstate water management organizations	<ul style="list-style-type: none"> Little progress has been made to date due to lack of political commitment
	Improvement of CA power transmission system	<ul style="list-style-type: none"> US\$175 million loan package from ADB and EBRD is being prepared Possible support from USAID for implementation of Power Trade Action Plan
	Further improvement of the Kyrgyz energy system	<ul style="list-style-type: none"> First steps to create enabling environment to attract private investment have been taken
	Irrigation rehabilitation, groundwater development and drainage water reuse in Ferghana Valley (Uzbekistan)	<ul style="list-style-type: none"> USAID and WB support project identification
	New storage reservoirs and water transfer projects in Uzbekistan	<ul style="list-style-type: none"> Preparatory work has started
Long-term 8 – 15 years	Construction of the Kambarata 1 and 2 hydropower projects (Kyrgyzstan)	<ul style="list-style-type: none"> USAID supports an evaluation of both projects and the dialogue between basin states on the next steps
	Further improvement of the operations of interstate water and energy systems	

1.2 Scope of this Report

This Report makes an assessment of the Kambarata 1 and Kambarata 2 hydropower projects in Kyrgyzstan using studies and data from the files of USAID, the World Bank, and several government agencies in the region. The Report looks at these projects in the context of Kyrgyzstan's energy system and also the interconnected CAR high voltage transmission grid. Annual energy generation is estimated for the projects, singly or in combination, and earlier estimates of project costs have been updated. The projects are compared to alternative sources of power and energy.

The Report's purpose is to help officials in Kyrgyzstan and the other states of the CAR, and potential financing agencies to decide whether or not to proceed with a more detailed assessment of the costs and benefits of these projects.

2. THE POWER SYSTEM OF THE CENTRAL ASIAN REPUBLICS

2.1 The Present Situation

The Central Asian Power System (CAPS) comprises 85 power stations with an installed generating capacity of close to 25,000 MW, of which 9,000 MW is hydropower plants and around 16,000 MW thermal power plants (see Table 2.1). High-voltage transmission lines link the power systems of the five countries for parallel operation. A schematic layout of the 500 kV transmission lines is shown in Figure 2.

The dependable capacity is now about 21,000 MW because many of the thermal plants date back to the 1960s and cannot perform at their original capacity. Most of the thermal plants in Uzbekistan and Turkmenistan are conventional gas-fired steam plants. In Kyrgyzstan and Tajikistan the thermal plants are multi-fuel combined heat and power (CHP) plants. The plants in South Kazakhstan are coal-fired.

The major hydropower plants are located in Kyrgyzstan (mainly the Naryn Cascade, 2,870 MW) and in Tajikistan (4,000 MW including the 3,000 MW project at the Nurek Reservoir). The main power plants and load centers are connected by a 500 kV transmission grid system that is in need of rehabilitation. The main facilities of the CAPS are summarized below.

Table 2.1 Central Asian Republics: Power Plants and Transmission Lines

Country	Installed Capacity (MW)		
	Thermal	Hydro	Total
Kazakhstan (South)	2,000	360	2,360
Kyrgyzstan	790	2,900	3,690
Tajikistan	300	4,000	4,300
Turkmenistan	2,600	0	2,600
Uzbekistan	9,800	1,700	11,500
Totals	15,490	8,960	24,450
	Transmission Lines (km)		
	500kV	220kV	
Kazakhstan (South)	1,080	1,300	
Kyrgyzstan	541	1,252	
Tajikistan	300	1,200	
Turkmenistan	370	2,000	
Uzbekistan	1,700	5,100	
Totals	3,991	10,852	

Under the Soviet regime, the CAPS were operated as an integrated system under the control of the Unified Dispatch Center (UDC) at Tashkent. Surplus energy from the hydropower plants displaced thermal energy in the summer, and Kyrgyzstan and Tajikistan imported energy from the thermal plants in the winter. Also, Kyrgyzstan and Tajikistan imported fuel in the winter for their CHP plants. The CAPS acted like a single, self-contained utility company; no money changed hands for the imports of fuel and energy. In 1990, energy generation reached 112,500 GWh, but then dropped sharply, followed by a slow recovery to 92,000 GWh in 2001 and a peak load of 15,500 MW.

Since the early 1990s to the present time, the republics have operated their generating plants in many ways as five independent power systems. Power exchanges still take place, but at a lower level than in the 1980s, and the hydropower plants continue to provide frequency control and system stability. Kyrgyzstan still imports fuel in the winter and exports surplus hydro energy in the summer under annual agreements with Uzbekistan and Kazakhstan.

But the fuel deliveries fall short of Kyrgyzstan's needs; this has led to a cutback in the output of the CHPs that in turn has driven up the consumption of electricity for home heating. A similar situation prevails in Tajikistan. The response in Kyrgyzstan has been to operate the main storage reservoir at Toktogul on the Naryn River (a tributary of the Syr Darya) to maximize output of the hydropower plants in the winter. This has created downstream water management problems (see Chapter 3).

2.2 Integrated Operation: Potentials and Problems

If the five countries were to integrate their power operations more fully than at present the following benefits would accrue:

- A more efficient use of resources by an "economic dispatch" in which thermal and hydro units are operated in a way that minimizes fuel and other operating costs.
- A sharing of generating capacity in order to reduce the reserve requirements of the individual systems.
- Operation of the hydropower plants to provide system stability, frequency control and rapid response peaking.
- Energy transfers to Kyrgyzstan and Tajikistan in the winter to supplement fuel deliveries.
- Rational use of the hydropower resources to ensure that all reservoir releases flow through the power plants (no spilling of water).
- A return to reservoir release patterns that accord with downstream irrigation and environment needs.

In recent years, the power operations in most of the five countries have been unbundled into separate generation, transmission and distribution companies. An economic dispatch would be of interest to generating companies if the import or export of energy or peaking capacity produces a financial gain. However, at the present time, gas prices in some countries are below market prices and in effect fuel costs are subsidized; this weakens the incentive to import energy.

Therefore, a prerequisite for efficient energy trading is uniform fuel pricing. The main obstacles to a return to an integrated system are differences in the economic and financial status of the five countries. Kazakhstan and Turkmenistan have large foreign exchange earnings from fossil fuel exports that can pay for new thermal generating capacity. Uzbekistan has its own gas resources but the foreign exchange for the purchase of new generating capacity is limited. Kyrgyzstan and Tajikistan have hydropower resources that are seasonal and leave them with large winter energy deficits, and they are short of fossil fuel and the foreign exchange needed for its purchase. There is some scope for Kyrgyzstan and

Tajikistan to trade their hydro energy in the summer for winter fuel and energy, but this option is limited by winter energy shortages in Uzbekistan and South Kazakhstan.

Nevertheless, power exchanges continue to be managed by the UDC for a variety of technical reasons, and also to allow the summer hydropower surplus to be absorbed under the 1998 Framework Agreement on the Use of Water and Energy Resources in the Syr Darya basin. The Naryn Cascade in Kyrgyzstan is consistently operated without spilling water but spilling has recently taken place at the Nurek plant in Tajikistan.

3. THE KYRGYZSTAN POWER SYSTEM

3.1 The Present Situation

The main source of power in Kyrgyzstan is the complex of hydropower plants on the Naryn River, known as “the Naryn Cascade”. The Naryn River is the main tributary of the Syr Darya and accounts for 30 % of its total runoff (see Figure 3). The Naryn Cascade (Figure 4) has an installed capacity of 2,870 MW that consists of the Toktogul Reservoir and its 1,200 MW power plant and four downstream run-of-river plants, Kurpsai (800 MW), Tashkumyr (450 MW), Shamaldysai (240 MW), and Uch-Kurgan (180 MW). Annual energy generation is about 10,600 GWh. There are also smaller hydroelectric projects in Kyrgyzstan that have an installed capacity of 70 MW. Annex C shows the basic data of the existing and planned larger hydropower projects.

The thermal energy generated is based on imported fuel for the Bishkek (680 MW) and Osh (50 MW) combined heat and power plants (CHP). These plants are intended to meet the deficit in hydro energy in the winter months and supply steam for the district heating systems of Bishkek and Osh. They are old and suffer from deferred maintenance and replacement; it is reported that the monthly energy that can be produced is no more than 250 GWh compared to 450 GWh in the 1980s.

The energy production of the Naryn Cascade is primarily determined by the outflow of water from the Toktogul Reservoir, and in part by the reservoir level. In the past three years the energy generated by Naryn Cascade was 11,906 GWh (1999), 13,414 GWh (2000) and 12,137 GWh (2001). In these years, inflow to Toktogul was above the long-term average of 12.0 bcm: 25% in 1999, 9% in 2000 and 9% in 2001. In 1999, the volume of water in the Toktogul Reservoir was increased by 0.9 bcm to 14.5 bcm by end of the summer, but in 2000 and 2001 the reservoir was depleted in order to enhance the energy output of the Cascade, and this process was continued in early 2002, with the reservoir being depleted to a volume of less than 8 bcm. The reservoir recovered in the summer of 2002 due to ample inflow, and also reduced releases at the request of the downstream riparians.

3.2 Power Operations in Relation to Water Management

One of the main transboundary water and energy issues in Central Asia is the operation of the Toktogul Reservoir in Kyrgyzstan, in the upstream reaches of the Syr Darya basin. Before 1991, when the Syr Darya was operated as an integrated water and power system, the summer releases from Toktogul averaged 8.1 bcm, or 71 percent of the inflow.

There were two reasons for the pre-1991 operating regime. First, was the desire to hold as much water as possible in the reservoir during the winter as a reserve against a low summer inflow. Second, was the need to avoid high winter flows into the Lower Syr Darya when its capacity is restricted by ice formations. Under this operating regime, the winter fuel needs of Kyrgyzstan’s 680 MW of combined heat and power (CHP) plants were supplied by the other republics. In addition energy was transmitted to the Kyrgyzstan through the CAR transmission grid when necessary.

Since independence in 1991, the energy demand patterns of Kyrgyzstan have changed drastically. At the same time, the fuel supply arrangements under the Soviet system were disrupted. Due to fuel shortages the output of the CHP plants was halved, giving rise to increased electric power demand by the population for heating, hot water supply and cooking,

stimulated by very low tariffs. To meet the high winter demand for electricity, the operation mode of the Toktogul Reservoir was switched from irrigation to electricity generation, which requires major water releases during winter when power demand is highest. As a result, the winter releases from the reservoir increased from average 2.7 bcm before 1991 to average 7.2 bcm since 1991 (or from 24% of average reservoir inflow before 1991 to 56% of average inflow after 1991).

The sharp increase in winter releases has caused a major environmental impact. Winter inflows to the Chardara Reservoir in Kazakhstan have risen by 30%. But the Lower Syr Darya does not have enough capacity in the winter to transport surplus flows to the Aral Sea; in part this is because of the poor condition of the structures on the river, numerous man-made obstacles, and also the formation of ice jams. In the 1980s, there was only one spill from Chardara into the nearby Arnasay Depression in Uzbekistan, but since 1992, annual spills have accumulated 30 bcm in the Depression. This has damaged land and infrastructure in Uzbekistan and deprived the Syr Darya Delta and the Northern Aral Sea of much-needed water.

The corresponding reduction in summer releases from the Toktogul Reservoir contributed to considerable water stress in Uzbekistan and reduction of the irrigated area in Kazakhstan. Since 1991, the summer releases from Toktogul Reservoir have averaged 6.0 bcm, only 46% of the inflow. The impact of the decline in summer releases on agriculture have been mitigated to some extent because farmers have switched some of their land from summer crops to winter wheat (planted in October and harvested in May/June). However, this change in the cropping pattern is believed to be mainly for economic reasons rather than a water shortage.

To address these problems, in the first half of the 1990's, the Syr Darya basin countries entered into a number of ad hoc annual agreements on water/energy exchanges between the upstream and downstream countries in the Syr Darya basin. In 1997, the Heads of States sought to place these agreements on a more formal footing. USAID/CAR provided technical assistance to high level ministerial delegations at various meetings and roundtables that led to the March 17, 1998 Framework Agreement between Kazakhstan, Kyrgyzstan and Uzbekistan on the Use of Water and Energy Resources of the Syr Darya Basin. Tajikistan became a party to this Agreement on June 19, 1998.

The main articles of the agreement provide for:

- Annual agreement on the operation of reservoirs of the Naryn-Syr Darya Cascade, the production of electricity, and the compensation for energy losses.
- The transfer of energy, in excess of the needs of Kyrgyzstan, in equal amounts to Uzbekistan and Kazakhstan.
- Compensation in equivalent amounts of energy resources, such as coal, gas, electricity, and fuel oil, or in monetary terms as agreed upon for annual and multi-year storage in the reservoirs.

The Agreement has a five-year validity that is automatically renewed unless any of the parties object. It serves as a basis for preparation of the annual bilateral and multilateral agreements on the use of water and energy resources of the Naryn-Syr Darya cascade of water reservoirs.

In 1998, high tributary flows greatly reduced the water demand in the Syr Darya basin and Toktogul releases were held to 3.8 bcm in the summer by mutual agreement. But, since then, the summer release has been close to 6 bcm. Fuel has been delivered to Kyrgyzstan as required, albeit with occasional delays. Data for 2001 shows that the deliveries for the winter of 2001/2002 were in line with agreements reached in mid-2001. Nevertheless, there is still a shortage of fuel for winter electricity generation in the Kyrgyz CHP plants; downstream countries still report irrigation water shortages; and losses in the Arnasay depression remain high.

To balance its shortage of fuel for winter energy generation, Kyrgyzstan has had to increase reservoir releases and power generation from Toktogul in the winter. In recent years, annual releases from the reservoir have substantially exceeded annual inflows, despite substantially higher than average inflows of water into the reservoir.

3.3 Load Forecast

Since independence in 1991, the demand patterns and the fuel-energy balance of Kyrgyzstan have changed drastically. Due to complications in intergovernmental relations and account settlements, introduction of national currencies, rising prices of oil, coal, natural gas and higher transportation costs, the supply of fuel to Kyrgyzstan was reduced. The loss of foreign markets for most of Kyrgyzstan's exports caused a sharp drop in the electricity demand of the industrial and agriculture sectors.

At the same time, the fuel supply arrangements under the Soviet system were disrupted and Kyrgyzstan experienced a shortage of fuel for the CHP plants. The decline in heat output led to a sharp rise in the use of electricity for domestic purposes. The drop in demands for industry and agriculture was more than offset by a rapid growth in residential demand that was further stimulated by very low tariffs. Since electricity losses are higher in the residential sector this also contributed to a four-fold increase in losses.

The dramatic redistribution of demand among consumer groups, and the corresponding growth in losses within the last ten years is illustrated in Table 3.1. This table is based on data provided by the State Energy Agency and shows a very high level of losses of 42% of gross consumption (generation plus imports minus exports).

Table 3.1 Demand by Consumer Group.

Consumer Group	Demand (GWh)			
	1991	1999	2000	2001
Industry	3,509	1,531	1,369	1,286
Commercial	1,178	1,262	1,365	1,551
Agriculture	1,986	656	586	508
Residential	1,455	3,802	4,455	3,179
Losses	1,064	3,740	3,839	4,806
Gross Consumption	9,192	11,222	11,876	11,572

The growth in gross consumption in recent years is largely due to the higher level of technical losses. Annex A shows monthly generation, imports and exports for the years 1999, 2000 and 2001, from which it can be seen that the January energy demand is more than three times the demand in the summer months, and percentage losses in the winter are much higher than in the summer.

As a result, the system load factor is very high in the winter months (over 80%); this is typical of a system where demand is limited by the supply. Tariffs are low, less than 1 US cent per kWh, and the rate of collection is poor. The resulting low revenue and Kyrgyzstan's low foreign exchange earnings limit the ability to purchase fuel to cover the fuel requirements needed in addition to what Kyrgyzstan imports from the downstream countries through the implementation of the 1998 Agreement (see previous section).

Kyrgyzstan depends for most of its energy on the seasonal output of its hydropower plants, which varies from month to month according to releases from the Toktogul Reservoir. Therefore a load forecast has to estimate the monthly as well as the annual demands. Also, the effect of loss-reduction programs (as recommended in the USAID TWEP report "Support to Electricity Loss Reduction in Kyrgyzstan" dated 23 September, 2002 by PA Consulting) has to be taken into account. Other factors that would tend to limit load growth are the impacts of higher tariffs and the constrained supply until new capacity is added to the Kyrgyzstan system.

In 2000, the electrical energy that was paid for by end-users was 7,800 GWh. The losses of 3,800 GWh in that year can be assumed to include 50% (1,900 GWh) of energy that was used but not paid for. Thus, the actual end use was possibly about 9,700 GWh. For the purposes of this report the demand by 2010 and 2015 assumes 1.3% annual growth in end use, technical losses of 18%, and a winter/summer ratio declining from 3.2 to 2.0. System load factors are assumed to be 65% in the winter and 55% in the summer. From now to 2005, the effect of loss reduction and higher tariffs will be small and it is assumed that gross consumption grows at 1.0 % annually. These assumptions lead to the load forecasts presented in Annex B. It should be noted that the findings of this report are not particularly sensitive to the load forecasts.

3.4 Alternative Toktogul Operating Regimes

The hydro energy produced by the Naryn Cascade in 1999, 2000, and 2001 was much higher than the long-term average. In those years the outflows were 13.1 bcm (1999), 14.8 bcm (2000) and 13.8 bcm (2001). Over the long term, the outflow should not normally exceed the average inflow of 12.0 bcm and this would produce on average about 10,700 GWh compared to the average for the last three years of 12,500 GWh. Therefore, the objectives of the operation studies are to examine, under conditions of average annual reservoir inflow, the effect of different operating regimes on (a) annual and seasonal energy shortages and the need for fuel and energy imports and (b) the peak monthly winter energy deficit. There are basically three operating regimes that could be adopted at Toktogul Reservoir:

- T65. This regime is similar to the pre-1990 situation, when the summer outflow from Toktogul was about 65 % of the annual inflow (7.8 bcm).
- T55. This regime is more or less similar to the present situation when a summer outflow of 6.5 bcm is maintained (this is 55 % of the average annual inflow).
- T22. This regime would concentrate most of the outflow in the winter months so that the summer outflow is only 2.7 bcm (this is 22 % of the average annual inflow).

A monthly operation study was run for the Naryn Cascade for an average flow year (12.0 bcm) for each of these regimes. It is assumed that 250 GWh is available in any month from the existing thermal plants. Demands are for the year 2005 (5 % higher than the Year 2000

demand). The calculations and results of the operation study are presented in Annex D and summarized in Table 3.2 below.

Table 3.2 Comparison of Toktogul Operating Regimes.

Results Operating Regimes	Regime (all figures in GWh)		
	T65	T55	T22
Annual Energy Demand	12,484	12,484	12,484
Hydro Energy Generation	11,012	10,983	10,732
Sum of Monthly Surpluses	3,559	2,355	0
Sum of Monthly Energy Deficits:	5,031	3,856	1,804
Supplied by Existing Thermal Plants	1,500	1,500	1,760
Supplied by Energy Imports	3,531	2,356	43
Net Annual Energy Deficit	1,472	1,501	1,804
Maximum Monthly Energy Import	784	666	43

The conclusions to be drawn from this analysis are as follows:

- The high level of hydropower generation since 1999 is not sustainable. It has (a) exaggerated the size of the summer energy surplus from the Naryn Cascade and (b) disguised the size of the overall energy deficit in the Kyrgyzstan Power System.
- The Kyrgyzstan Power System will face large and growing energy deficits in the years before Kambarata 1 might be in service. Kambarata 2 would not significantly relieve the winter energy shortage because it produces only 290 GWh in the winter. Summer production of about 970 GWh would increase the hydro surplus that can be traded for winter fuel and thereby reduce the annual surplus.
- None of the operating regimes, even Regime T22, the most extreme "power oriented," eliminates the need for either large imports of fuel for the existing thermal power plants or imports of electrical energy.
- The annual hydro energy generated differs little between the three regimes. The high summer flow regimes (T65 and T55) tend to operate at higher heads during the high flow months and, therefore, produce slightly more annual energy than Regime T22. In other words, the "irrigation regimes" produce more annual energy than a "power regime".
- The annual energy deficit does not differ greatly between the three regimes, but the seasonal distribution of deficits and surpluses are quite different. In Regime T22, there are no months with a hydro surplus because of the concentration of reservoir releases in the winter, and most of the winter deficit is met by running the existing thermal plants. In Regimes T65 and T55, there are large summer surpluses and most of the winter deficit is met from imports of energy.

The very low reservoir release in the main growing season of Regime T22 would be unacceptable to the downstream riparians and remove their incentives to deliver winter fuel and energy through implementation of the 1998 Agreement. One of the main problems

created by the post-Soviet operation at Toktogul has been environmental; namely the large unusable winter releases spilled into the Arnasay Depression Regime. T65 has an advantage over Regime T55 in that it might be more effective in reducing spills into the Arnasay Depression and increasing the flow into the Northern Aral Sea. An ongoing World Bank-financed project is designed to remove some of the structural obstacles to winter flow in the Lower Syr Darya. The outcome of this project will have a bearing on the choice of operating regime for Toktogul.

4. THE KAMBARATA 1 AND 2 PROJECTS

4.1 Existing Studies and Data

In 1993, Harza Engineering Company, under contract to USAID, prepared a report entitled "Evaluation of the Hydroelectric Development Program of Kyrgyzstan". Kambarata 1 and Kambarata 2 and other smaller hydroelectric projects were reviewed using data from investigations and plans made in the Soviet era.

Kambarata 1 and Kambarata 2 are on the Naryn River (Figure 2) and are the largest projects listed in the Harza Report. While many sites for hydropower development have been identified in Kyrgyzstan, their winter energy production is very low. Some small-scale hydropower projects have been built and others might be developed to serve local communities.

For Kambarata 1, two types of dam were considered: an arch dam and a rock-fill dam. The rock-fill alternative would employ a method pioneered by Soviet engineers in which the sides of the valley are blasted to form a dam, termed a "blast-fill dam". For Kambarata 2, two alternatives were considered, a rock-fill dam and blast-fill dam. The Harza report has drawings, construction quantities, and unit prices for both alternatives.

The main features of the two projects are as follows:

	<u>Kambarata 1</u>	<u>Kambarata 2</u>
Height of dam	245 m	60 m
Gross Reservoir Volume	4,500 mcm	70 mcm
Dead Storage Volume	380 mcm	62 mcm
Average Annual Reservoir Inflow	10,463 mcm	approx. same as Kambarata 1
Maximum Head	233 m	50 m
Minimum Head	106 m	47 m
Installed Capacity	1200/1600 MW	400/600 MW

4.2 Dam Alternatives Considered

For this Report, the arch dam alternative (Figures 5 and 6) was used as a basis for the Kambarata 1 cost estimate since there are no blast-fill dams that have been subject to international competitive bidding. Harza proposed an installed capacity of 1,700 MW for the arch dam alternative. The intent was apparently to export power to other Asian countries outside of the CAR (a 706 km transmission line was proposed). With Kambarata 1 and Kambarata 2 on line, Kyrgyzstan would have a surplus of peaking capacity and would be in a position to export power within the CAR.

However, it should be noted that the export of peaking capacity involves some export of energy that will still be in short supply in the winter (for example, export of 1,000 MW for three hours per day requires 90 GWh in one month). For the needs of Kyrgyzstan alone, an installed capacity of 1,200 MW has been adopted for Kambarata 1 since this would be sufficient to exploit the full energy potential of the site. It would be a simple matter to install

additional units in the future, and the cost estimate covers the works needed to permit such expansion.

The rock-fill alternative (Figures 7 and 8) was used for the Kambarata 2 estimate. Harza proposed an installed capacity of 350 MW. For Kambarata 2 as a single project this study adopts a capacity of 400 MW (2X200 MW) in the absence of Kambarata 1. For Kambarata 2, with Kambarata 1 in place, the winter energy generation (but not the annual energy generation) would be higher and therefore a third 200 MW unit could be installed to bring the capacity to 600 MW.

5. COST ESTIMATES

5.1 Kambarata 1

The Ertan Hydroelectric Project in China, completed in 2000, was used as a reference for unit prices (quoted by the lowest bidders) to be applied to the Harza quantities. Ertan has a 240 m high arch dam and an installed capacity of 3,300 MW. Details of the cost estimate are given in Annex F.

The main changes from the Harza estimate are:

- An installed capacity of 1,200 MW (see above) instead of the Harza plan for 1,700 MW. The civil works for the 1,700 MW are retained so that the estimate covers future expansion.
- A cost/kW for generators and turbines of US\$ 120 based on the Ertan costs.
- A 20 % contingency is applied only to the civil works.
- Additions to the Harza estimate included higher costs for the preparatory works and mobilization; an item for river diversion and care of water.
- A 260 km transmission line to connect Kambarata 1 to Northern Kyrgyzstan and Kazakhstan instead of a 706 km line.

The result is a cost for Kambarata 1, of US\$ 970 million in 1990 prices. It then becomes necessary to convert this 1990 price to constant 2002 US dollars. An accepted World Bank method to convert past costs to constant dollars is to apply the Index of the Value of Manufactured Export, commonly referred to as the MUV Index.

The following table shows figures from May 2002 of the Worlds Bank's Economic Policy and Prospects Group (the Index base level is 2001):

1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001
104.2	106.3	110.4	111.2	115.2	122.0	116.0	107.9	103.8	103.5	101.5	100.0

The estimated figure for 2002 is 99.5. Thus, for practical purposes the 1990 cost is essentially the same when converted to 2002 constant dollars. However the situation at Ertan was more favorable than at Kambarata 1. Ertan was well served by a railway, and the Chinese economy could provide cement, steel etc. at competitive prices. Thus, the 2002 cost has been raised by 20% to allow for this and it becomes US\$ 1,163 million.

5.2 Kambarata 2

The Harza unit prices were used except where the Ertan prices were considered more appropriate. Details of the cost estimate are given in Annex F. The main changes from the Harza estimate are:

- A cost/kW for generators, turbines transformers of US\$ 130 (based on a lower head than Kambarata 1).

- An initial installed capacity of 400 MW, increased to 600 MW when Kambarata 2 is operated in conjunction with Kambarata 1.
- A 20% contingency is applied only to the civil works.
- Additions to the Harza estimate included an item for river diversion and care of water.

Some work has already been done at the site, including the construction of diversion tunnels, but no allowance is made for this in the cost estimate. The cost in 1990 dollars is US\$ 227 million. After the same adjustments as for Kambarata 1, the cost is US\$ 280 million.

6. BENEFITS TO THE CAR AND KYRGYZSTAN ENERGY SYSTEMS

6.1 Results of System Operation Studies

The purpose of the system operation studies is to estimate monthly and annual energy produced by the Kambarata Projects along with Toktogul and the other hydropower projects in the Naryn Cascade. This output is then compared to monthly system demands in order to arrive at deficits and surpluses in monthly energy and power generation after allowance for the output of existing thermal power plants. Details of the system operation studies are given in Annex E.

These power and energy balances are carried out for the years 2010, the earliest at which Kambarata 1 could be on line, and 2015, possibly several years after Kambarata 1 is in service. For Kambarata 2, as a stand-alone project, its in-service date is left indeterminate since neighboring CAR countries could absorb its peaking capacity as soon as it could be built. Without Kambarata 1, Kambarata 2 is mainly a summer energy producer and would do little to solve Kyrgyzstan's winter energy problem.

The annual inflow to Kambarata 1 is about 88% of the inflow to the Toktogul Reservoir. Stream flow data and the characteristics of reservoirs and power plants are taken from the Soviet records.

The studies are made for Kambarata 1 with Kambarata 2, and also for Kambarata 2 alone. In all cases they are combined with the existing Naryn Cascade. The live storage capacity of Kambarata 1 is 4.12 bcm. With that capacity the project could be operated without spilling water past the powerhouse. In other words the entire flow of the Naryn River at the site would be fully controlled and regulated. Although the operation of Kambarata 1 would modify the seasonal pattern of inflow to the Toktogul Reservoir it would not in any way limit the operators of Toktogul Reservoir in their choice of monthly releases patterns. This is because the live storage of the Toktogul Reservoir is so large, almost equal to the average annual inflow, that it allows a high degree of regulation. All studies are done for an average water year.

The Kambarata 1 reservoir is operated to meet certain targets for the reservoir content at the end of each month. A rule curve defines the end-of-month reservoir content. For example, if the figure for January is 0.65, the end-of-month content is $0.65 \times 4,500$ million cubic meters (mcm). Two rule curves were adopted in the alternatives examined. Rule Curve RW is designed to maximize the winter energy production; this requires drawing on the live storage of the reservoir of 4.12 bcm in the winter months. Rule Curve RA aims to maximize the annual energy production by keeping the reservoir at its maximum level most of the year except when (a) it is drawn down a small amount in the winter months to improve the performance of Kambarata 2 and (b) held to 90% of reservoir capacity in May and June for flood control purposes. A manual adjustment of the monthly releases between October and March is made to produce a more or less even amount of monthly energy in the winter months. In all the options studied the Toktogul reservoir is operated to provide a specified release in the summer.

The storage at Kambarata 2 is too small to provide seasonal regulation, but it can provide daily regulation. Without Kambarata 1, the energy production of Kambarata 2 in the winter months is so low that it could run at full capacity for only two to three hours. With the

Kambarata 1 operating upstream, the winter energy is increased and its capacity as a peaking plant can be raised from 400 MW to 600 MW. A separate study is made of Kambarata 2 as a stand-alone peaking project. The results obtained are summarized in Table 6.1, and details are presented in Annex E. Alternatives A and B with a summer outflow of 7.8 bcm at Toktogul show the effects of rule curves for maximizing annual energy or winter energy. Alternatives C and D with a summer outflow of 6.5 bcm also show the effects of the two rule curves.

Table 6.1 Comparison of Alternatives for the Year 2015

Results	Alternative (All figures in GWh except where noted)			
	Alternative A	Alternative B	Alternative C	Alternative D
Toktogul Regime	T65	T65	T55	T55
Summer Outflow from Toktogul	7.8 bcm	7.8 bcm	6.5 bcm	6.5 bcm
Rule Curve	RW	RA	RW	RA
Energy Demand	13,893	13,893	13,893	13,893
Hydro Energy Generation	16,893	17,956	16,879	17,946
- Kambarata #1	4,624	5,737	4,624	5,737
- Kambarata #2	1,256	1,256	1,256	1,256
- Cascade	11,014	10,963	11,000	10,954
Summer Hydro Surplus	4,334	7,077	3,196	5,941
Winter Demand minus Hydro:	1,334	3,014	209	1,888
- Supplied from Existing Thermal	1,168	1,500	209	1,469
- Supplied by Energy Imports	166	1,514	0	538
Max. Monthly Import	121	429	0	214
Annual Energy Surplus	3,000	4,063	2,986	4,053
Summer Peak Surplus	2,862 MW	2,953 MW	2,853 MW	2,954 MW
Winter Peak Surplus	894 MW	1,196 MW	871 MW	1,173 MW

The positive feature of Alternative C in comparison with the other alternatives is the lowest winter demand on the existing thermal plants. This alternative is adopted as a basis for the discussions and economic analyses that follow in this report; it involves a summer release from Toktogul of 6.5 bcm, and a rule curve that maximizes winter energy. The downstream riparians might favor a somewhat higher summer release from Toktogul in most years; this could be accommodated without a major change in the monthly pattern of the energy deficit.

6.2 Contribution to the Kyrgyzstan Energy System

The basic problem with the Kyrgyzstan power system is that the Naryn Cascade and the existing thermal plants cannot meet winter energy demand. By the Year 2005, with no additional capacity in service and average river flows, Kyrgyzstan will have an annual energy deficit of about 1,500 GWh, composed of a winter deficit of 3,900 GWh and a summer

surplus of 2,500 GWh (Table 3.2). This assumes the existing thermal plants will be available in all months to produce 250 GWh. Under present conditions, the peak monthly deficit will be 760 GWh, which is equivalent to the continuous output of a 1,000 MW power plant. The energy deficits have not reached these levels in the past because of unusually high inflows coupled with unsustainable withdrawals from the Toktogul Reservoir.

At present, Kyrgyzstan imports fuel in the winter and surplus hydro energy is exported under the terms of the 1998 Framework Agreement. Unfortunately, this alone is not enough to meet the winter deficits. A large block of winter energy will soon have to be imported from Uzbekistan or Kazakhstan or both. Thus, the importation of winter energy could conceivably be financed by the sale of the summer hydro surplus. Kyrgyzstan will soon face more severe shortages than have been experienced in recent years. Hydro energy generation has been 30% above sustainable levels. Table 3.2 shows that the large deficits far exceed Kyrgyzstan's existing thermal capacity (that relies on imported fuel). Rehabilitation of existing thermal plants is urgently needed.

Of the two upstream hydropower projects, Kambarata 2 could come on line at the earliest in 2007. But this project's annual output of only 1,260 GWh (290 GWh in the winter) would not help significantly to relieve the winter energy deficit. By 2015, with Kambarata 1 and Kambarata 2 in the system, Kyrgyzstan would have an annual energy surplus, mostly in the summer months of about 3,000 GWh and considerable excess peaking capacity, and the winter energy deficit would be eliminated.

Thus, the main elements of a power development plan for Kyrgyzstan are:

- Rehabilitation of the existing thermal power plants at Bishkek and Osh to restore their capacity to 680 MW and 50 MW respectively.
- Continued imports of fuel and energy in return for exports of the summer hydro surplus under the 1998 Framework Agreement.
- Completion of the Kambarata 1 project and Kambarata 2 Projects.
- An aggressive program to reduce losses from the present level of over 40% to no more than 18% (losses of 18% are assumed in the operation studies described in Chapter 6).
- A program to encourage consumers to move from electric heating to gas heating, and where possible coal heating.
- Investigation of Kyrgyzstan's coal resources as a base for thermal power (in the 1980's, over one million tons of coal was mined in the Kyrgyzstan, but production is now down to 100,000 tons).

6.3 Contribution to the Central Asian Power System

As noted above, Kambarata 2, without Kambarata operating upstream would produce most of its 1,260 GWh energy in the summer, and this would be of value to trade for winter energy. It could also be of interest to South Kazakhstan or Uzbekistan as a peaking plant with a capacity of 400 MW as a stand-alone project, or with 600 MW after completion of Kambarata 1. The project might be a possibility for private financing.

If Kambarata 1 and Kambarata 2 were both in service (installed capacity of 1,800 MW) there would be capacity in excess of Kyrgyzstan's needs of 1,000 MW in the winter and 2,800 MW in the summer (this includes the surplus summer peaking capacity of the Cascade), and a hydro energy surplus in the summer months of 3,000 GWh. Hydropower plants are also valuable components of a mixed thermal-hydro system because they respond quickly to sudden load changes and provide frequency regulation and system stability.

7. ECONOMIC FEASIBILITY

7.1 Method of Analysis

One way to test the competitiveness of a hydropower project is to compare two alternative system expansion plans. The project in question is included in one plan and in the second plan its place is taken by the least-cost alternative. The operation of the two plans is then simulated on a monthly basis for about 30 years, and all capital and recurrent costs are then discounted to the present at an appropriate discount rate. The plan with the lowest present value is the preferred solution.

However, such a method calls for more data than is currently available for the Kyrgyzstan power system and, therefore, a direct comparison of Kambarata 1 with a thermal power alternative has been adopted. Possible thermal alternatives are a coal-fired steam plant fuelled by imported coal or coal from Kyrgyzstan's Kara Keche mine, or a gas-fired plant fuelled by imported gas. There are no current estimates of the coal-fired option and it is unlikely to be less costly in capital or operating costs than a gas-fired plant. Therefore, the least-cost alternative adopted is a gas-fired combined cycle plant. The analysis includes:

- A comparison with the least-cost alternative that produces an equalizing discount rate (EDR). This is the rate that equalizes the present value of the cost streams of the hydro project and the least-cost alternative. A hydro project has a high capital cost and low operating cost, whereas the reverse is true for a thermal power project. A low discount rate favors a hydro project, but its justification must rest on an acceptable discount rate. In general this is taken as the opportunity cost of capital that is often assumed to be in the range of 10-12%.
- Calculation of the economic rate of return (ERR), in which the benefit stream is the average annual energy production (after losses and station use) priced at the higher of the retail tariff or the consumers' willingness to pay.

7.2 Kambarata 1

Kambarata 1 is compared to a 1,200 MW gas-fired combined cycle with a capital cost of US\$ 750/kw (including additional pipeline capacity) and a fuel cost of 2 cents per kWh (based on the current Uzbekistan export price of US\$ 54 per 1,000 cubic meters). With these assumptions, the EDR is 11%. For the economic analysis, a willingness to pay of 6 cents/kWh and losses of 20% were assumed. This gives an ERR of 12%.

It can be concluded from this analysis that Kambarata 1 is competitive with the least-cost thermal alternative. It also has the considerable advantage that it avoids the use of imported fuel. If the scarcity value of foreign exchange were taken into account, Kambarata 1 would become more attractive.

Even though operation of the power systems of the CAR countries is less integrated than in the Soviet times, hydroelectric plants still have a role in providing system stability. As the CAR systems grow, the role of the Naryn Cascade and Kambarata 1 will become more important. However, the benefits of Kambarata 1 in terms of frequency control and spinning reserve have not at this stage, been quantified.

7.3 Kambarata 2

Kambarata 2 would operate as a peaking plant. If it were built and operated in the absence of Kambarata 1, it would be a 400 MW plant, with provision for future installation of a third 200 MW unit on the completion of Kambarata 1. Kambarata 2 has been compared to a gas turbine, commonly installed for short-duration peaking, with a capital cost of US\$ 400/kw and a fuel cost of 2.4 cents per kWh. With these assumptions, the EDR is 15%. With the same assumptions as Kambarata 1, the ERR is 13%. It can be concluded from this analysis that Kambarata 2 is competitive with the least-cost thermal alternative.

8. WATER MANAGEMENT, SOCIAL, AND ENVIRONMENTAL IMPACTS

The basic problem with the Kyrgyzstan power system is that the hydropower projects of the Naryn Cascade (the 1,200 MW Toktogul dam and reservoir, and 1,670 MW of run-of-river hydropower plants), produce most of their energy in the summer, whereas the peak energy demand is in the winter months. The result is a high winter demand on the existing thermal power plants that requires large imports of fuel and energy. Consequently, the operators of Toktogul aim to maximize reservoir releases and energy production in the winter and minimize reservoir release to the downstream countries in the summer.

To address this energy/irrigation conflict, the Syr Darya basin countries entered into the March 17, 1998 Framework Agreement between Kazakhstan, Kyrgyzstan and Uzbekistan on the Use of Water and Energy Resources of the Syr Darya Basin. Tajikistan became a party to this Agreement on June 19, 1998. This provides for winter fuel to be delivered to Kyrgyzstan in return for sales of hydro energy in the summer months.

The sharp increase in winter releases in the 1990s has also caused a major environmental impact. Winter inflows to the Chardara Reservoir in Kazakhstan have risen by 30%. But the Lower Syr Darya does not have enough capacity in the winter to transport surplus flows to the Aral Sea; in part this is because of the poor condition of the structures on the river, numerous man-made obstacles, and also the formation of ice jams. In the 1980s, there was only one spill from Chardara into the nearby Arnasay Depression in Uzbekistan, but since 1992, annual spills have accumulated 30 bcm in the Depression. This has damaged land and infrastructure in Uzbekistan and deprived the Syr Darya Delta and the Northern Aral Sea of much-needed water.

This report looked at the effect on Kyrgyzstan's winter energy shortage of different operating regimes for the Toktogul Reservoir in the years before Kambarata 1 would be in service. It was found that none of the operating regimes, even the most extreme "power oriented regime", eliminates the need for large imports of fuel and energy under present conditions. By the Year 2005, with no additional capacity in service and average river flows, Kyrgyzstan will have an annual energy deficit of about 1,500 GWh, composed of a winter deficit of 3,900 GWh and a summer surplus of 2,400 GWh. The energy deficits have not reached these levels in the past because of unusually high reservoir inflows coupled with unsustainable withdrawals from the Toktogul Reservoir. Hydro energy generation has been 30% above sustainable levels. It is clear, therefore, that Kyrgyzstan's needs for imports of fuel and energy will continue to grow until new capacity is installed.

The addition of Kambarata 1 will eliminate the winter deficits and thereby eliminate the conflict in the operation of the Toktogul Reservoir between the irrigation and environmental needs of the downstream countries and the winter energy needs of Kyrgyzstan. Kambarata 2 would add to Kyrgyzstan's summer hydro surplus that could be exchanged for fuel imports, but it would not significantly reduce the winter energy deficits.

The adverse social and environmental impacts of Kambarata 1 and Kambarata 2 appear to be quite limited. The reservoirs are reported to have no permanent residents and only a few livestock herdsman. Nevertheless, a detailed social and environmental study should be carried out.

9. NEXT STEPS

A workshop was held in Bishkek on February 25-26, 2003 to seek the comments of Kyrgyzstan power sector officials on the report. This led to useful suggestions on technical issues and a valuable exchange of views on the regional aspects of the two projects. This report reflects the findings of the workshop.

Following discussion of this report with energy sector officials in Kazakhstan, the next steps are likely to be as follows:

- Set up a Working Group of Kyrgyzstan and Kazakhstan experts to oversee the following activities.
- Prepare more detailed feasibility studies for the two projects. These would include an investigation of the possibility of staging Kambarata 1 including an analysis of different configurations of the 500 kV transmission network. The studies would present in more detail the costs and benefits of the projects and their contribution to the power systems of Kyrgyzstan and its neighbors, and their impact on water management.
- Investigate possible financing and institutional arrangements for further development of the projects.




Figure 1. Aral Sea Basin




Figure 2. The CAPS Grid




Figure 3. Water and Hydropower Facilities of the Syr Darya Basin




Figure 4. The Naryn Cascade

ANNEX A: KYRGYZSTAN POWER SYSTEM-GENERATION, IMPORTS AND EXPORTS

YEAR 1999	Totals	Jan	Feb	March	April	May	June	July	August	Sept	Oct	Nov	Dec
Total Generation	13,119	1,641	1,327	1,400	999	664	662	1,093	1,021	536	804	1,356	1,616
Thermal	982	197	158	157	62	28	15	14	14	28	53	107	150
Hydro	12,138	1,444	1,169	1,243	937	637	647	1,079	1,008	508	750	1,250	1,466
	4,991	629	493	514	371	198	226	423	425	199	316	554	644
Toktogul	3,353	409	333	363	266	187	176	289	270	133	199	334	394
Kurpsai	1,918	210	175	192	149	123	119	184	160	83	116	189	218
Tashkumyr	685	67	56	64	56	46	48	70	61	32	41	61	83
Sharnaldysai	959	110	95	94	82	61	57	85	73	36	57	96	114
UchKurgan	54	10	9	7	5	3	2	3	3	6	3	2	1
Small Hydro	50	2	2	1	1	6	6	7	7	7	7	4	2
Small Hydro	127	7	8	6	7	13	14	19	10	13	11	10	10
Import													
TPBishkek	918	179	142	145	62	28	15	14	14	28	53	103	136
TP Osh	64	18	16	12	0	0	0	0	0	0	0	4	15
	4	0	1	0	0	0	1	0	0	0	0	0	0
Tajikistan	185	0	0	0	0	23	58	32	28	43	0	0	2
Uzbekistan	138	0	0	0	0	14	26	27	28	43	0	0	0
Kazakhstan	2	0	0	0	0	0	0	0	0	0	0	0	2
Turkmenistan	46	0	0	0	0	9	32	5	0	0	0	0	0
	49	0	0	0	0	0	0	0	0	0	49	0	0
Export	1,999	15	18	72	105	67	196	596	516	62	143	141	69
Uzbekistan	970	2	0	0	0	21	148	413	387	0	0	0	0
Kazakhstan	880	14	12	15	19	46	48	184	128	62	143	141	69
Tajikistan	149	0	6	57	86	0	0	0	0	0	0	0	0
China	0	0	0	0	0	0	0	0	0	0	0	0	0
Losses in Kazakhstan	136	11	8	10	13	12	9	0	5	8	13	20	27
Gross Consumption	11,222	1,614	1,302	1,318	882	609	516	529	529	509	697	1,196	1,522
	0	0	0	0	0	0	0	0	0	0	0	0	0
Station Use	190	30	26	28	13	8	6	5	5	7	12	21	29
System Use	42	10	9	7	1	0	0	0	0	1	1	2	9
	0	0	0	0	0	0	0	0	0	0	0	0	0
Losses	3,739	686	512	518	255	168	107	121	118	94	197	455	509
Sales	7,252	888	754	766	612	434	404	402	406	408	486	718	975

YEAR 2000		Totals	Jan	Feb	March	April	May	June	July	August	Sept	Oct	Nov	Dec
Total Generation		14,862	1,737	1,633	1,413	847	932	1,098	1,422	1,263	613	1,040	1,301	1,562
Thermal		1,210	157	151	118	47	23	34	44	44	52	80	203	256
Hydro		13,652	1,580	1,482	1,295	800	909	1,064	1,379	1,219	561	960	1,098	1,306
Toktogul		5,580	689	628	522	295	331	422.1	572	510	224	388	454	545
Kurpsai		3,719	430	410	358	217	242	286.6	377	335	152	260	298	354
UchKurgan		1,061	120	116	100	69	77	82.1	102	88	39	77	86	106
Tashkumyr		2,157	234	224	202	145	163	173.9	212	188	90	154	172	200
Shamaldysai		897	89	86	79	59	69	74.2	91	81	38	66	77	90
Small Hydro		25	7	8	4	1	3	2.4	0	0	0	0	0	0
Small Hydro		52	2	2	3	4	7	6.5	7	7	7	3	2	2
Small Hydro		161	10	8	27	11	17	16.2	18	10	12	13	10	9
Import		1,164	144	145	118	47	23	34	44	44	52	79	192	240
TPBishkek		46	12	6	0	0	0	0	0	0	0	1	11	16
TP Osh		320	0	0	0	0	19	67	39	0	45	33	22	95
Tajikistan		126	0	0	0	0	19	67	39	0	0	0	0	0
Uzbekistan		195	0	0	0	0	0	0	0	0	45	33	22	95
Kazakhstan		0	0	0	0	0	0	0	0	0	0	0	0	0
Turkmenistan		0	0	0	0	0	0	0	0	0	0	0	0	0
Export		3,153	103	56	52	117	368	614	907	722	132	75	3	5
Uzbekistan		1,926	0	2	0	0	289	441	678	516	0	0	0	0
Kazakhstan		1,073	103	52	24	9	63	173	229	205	132	75	3	5
Tajikistan		154	0	2	28	108	17	0	0	0	0	0	0	0
China		0	0	0	0	0	0	0	0	0	0	0	0	0
Losses in Kazakhstan		179	28	27	22	8	8	6	6	6	7	17	19	24
Gross Consumption		11,876	1,606	1,550	1,322	722	576	546	553	542	525	990	1,310	1,636
Station Use		0	0	0	0	0	0	0	0	0	0	0	0	0
System Use		214	30	27	24	11	7	8	9	9	10	15	29	35
Losses		44	10	9	6	1	0	0	1	1	1	3	4	9
Sales		0	0	0	0	0	0	0	0	0	0	0	0	0
Losses		3,839	684	660	555	205	118	109	95	85	80	296	406	546
Sales		7,779	882	854	738	506	451	428	447	447	434	676	871	1045

YEAR 2001		Totals	Jan	Feb	March	April	May	June	July	August	Sept	Oct	Nov	Dec
Generation	Hydro	13,553	1,666	1,553	1,265	845	682	955	1,286	1,075	705	870	1,039	1,612
		12,337	1,410	1,406	1,148	789	646	916	1,246	1,038	637	772	903	1,426
Thermal	Toktogul	1,215	256	146	117	56	36	39	40	37	67	98	136	186
		4,787	565	556	431	277	211	347	506	417	247	301	357	571
	Kurpsay	3,457	397	404	330	226	176	251	350	291	172	214	247	399
		973	118	115	99	64	57	70	81	72	46	61	74	116
	Uch-Kurgan	2,006	220	222	191	143	121	153	200	165	104	121	142	224
		915	99	100	85	66	56	71	92	77	47	55	66	102
	Sharnaldy-Say	50	2	2	3	4	7	6	7	7	6	3	2	2
		150	8	8	10	11	18	17	11	10	16	16	14	12
	At-Bashy	1,166	241	135	110	56	36	39	40	37	67	98	136	171
		49	15	12	8	0	0	0	0	0	0	0	0	15
Import	Osh TPP	322	63	5	0	0	0	0	16	16	3	50	123	46
		35	0	0	0	0	0	0	16	16	3	0	0	0
	Tajikistan	287	63	5	0	0	0	0	0	0	0	50	123	46
		0	0	0	0	0	0	0	0	0	0	0	0	0
	Uzbekistan	0	0	0	0	0	0	0	0	0	0	0	0	0
		0	0	0	0	0	0	0	0	0	0	0	0	0
	Kazakhstan	0	0	0	0	0	0	0	0	0	0	0	0	0
		0	0	0	0	0	0	0	0	0	0	0	0	0
Export	Turkmenistan	2,165	10	13	45	44	87	419	739	567	160	68	12	1
		1,038	0	0	0	0	48	245	458	287	0	0	0	0
	Uzbekistan	1,049	10	9	4	11	39	175	282	280	160	68	11	1
		78	0	4	41	33	0	0	0	0	0	0	0	0
	Tajikistan	0	0	0	0	0	0	0	0	0	0	0	0	0
		0	0	0	0	0	0	0	0	0	0	0	0	0
	China	170	23	28	20	12	8	6	5	7	6	11	17	28
		0	0	0	0	0	0	0	0	0	0	0	0	0
Losses in Kazakhstan	Gross Consumption	11,572	1,700	1,522	1,196	786	592	531	562	522	546	850	1,135	1,630
		219	36	28	22	11	8	8	10	10	11	16	25	34
Station Use	System Use	22	7	8	5	1	0	0	0	0	0	0	0	0
		4,806	813	652	445	252	171	152	169	148	150	382	533	939
Losses	Sales	6,525	844	833	724	522	412	371	383	364	385	452	577	658

ANNEX B: LOAD FORECAST

Year	Totals	J	F	M	A	M	J	J	A	S	O	N	D
2000 Gross Consumption GWh	11,876	1,606	1,550	1,322	722	576	546	553	542	525	990	1,310	1,636
2005 Energy Demand GWh	12,482	1,688	1,629	1,389	759	605	574	581	570	552	1,040	1,377	1,719
System Load Factor %		80	80	70	65	65	65	65	65	65	70	75	80
2005 Peak Demand		2,890	2,789	2,719	1,599	1,276	1,209	1,225	1,201	1,163	2,036	2,515	2,944
2000 End Use GWh	9,700												
2010 End Use GWh	11,037												
2015 End Use GWh	11,774												
Monthly Distribution (%)		11.4	11.4	10.1	8.1	5.9	5.7	5.7	5.7	5.8	8.8	10.0	11.4
System Load Factor (%)		65	65	65	55	55	55	55	55	55	65	65	65
2010 Energy Demand GWh	13,024	1,485	1,485	1,315	1,055	768	742	742	742	755	1,146	1,302	1,485
2010 Peak Demand (MW)		3,129	3,129	2,772	2,628	1,914	1,849	1,849	1,849	1,881	2,415	2,745	3,129
2015 Energy Demand GWh	13,893	1,584	1,584	1,403	1,125	820	792	792	792	806	1,223	1,389	1,584
2015 Peak Demand (MW)		3,338	3,338	2,957	2,372	1,727	1,669	1,669	1,669	1,698	2,577	2,928	3,338

Assumptions:

1. 2005 Energy Demand assumes 1% annual growth in gross consumption.
2. Year 2000 end use is 2000 sales of 7,800 GWh plus 1,900 GWh (50% of losses) (see Annex A).
3. For 2010 and 2015, Annual growth in end use is 1.3 %.
4. Technical Losses: 18%.
5. Monthly energy distribution and system load factors as shown. See Annex A (Page 2) for 2000 load factors.

ANNEX C: HYDROPOWER PROJECTS: BASIC DATA

Toktogul						Kambarata 1 (planned)					
Pool Level	Gross Reservoir Capacity	Head	GWh/mcm	MW		Pool Level	Gross Reservoir Capacity	Head	GWh/mcm	MW	
	mcm	m					mcm	m			
	V	H					V	H			
900	19,400	176	0.421	1200		1200	5080	242			
890	17,000	164	0.394	1123		1190	4,500	233	0.560	2000	
880	14,800	154	0.369	1052		1150	2,680	192	0.459	1645	
870	12,500	143	0.343	977		1100	1,220	141	0.339	1213	
860	10,400	133	0.319	910							
850	8,000	122	0.292	832							
840	6,000	112	0.269	768							

$$H = 85 + (V/212)$$

$$Gwh/mcm = H * 2724 * 0.88 / 10^6$$

$$H = 87.8 + 48.12V - 3.5V^2$$

$$Gwh/mcm = H * 2724 * 0.88 / 10^6$$

Kambarata 2 (planned)		Average head 50 m , Gwh/mcm=0.120	350 MW
Kurpsai		Average head 92 m , Gwh/mcm=0.221	800 MW
Tashkumyr		Average head 53 m , Gwh/mcm=0.127	450 MW
Shamaldysai		Average head 26 m , Gwh/mcm=0.062	240 MW
Uch-Kurgan		Average head 29 m , Gwh/mcm=0.070	180 MW

ANNEX D: Toktogul Operating Regime T 22 (Summer 22%, 2,700 mcm)

	J	F	M	A	M	J	J	A	S	O	N	D	
Toktogul													
Inflow mcm	401	355	405	688	1,554	2,480	2,280	1,439	790	684	512	434	12,022
Outflow mcm	1,700	1,700	1,611	700	400	400	400	400	400	1,200	1,500	1,611	12,022
Reservoir BOM	16,888	15,589	14,244	13,038	13,026	14,180	16,260	18,140	19,179	19,500	18,984	17,996	
Reservoir EOM	15,589	14,244	13,038	13,026	14,180	16,260	18,140	19,179	19,400	18,984	17,996	16,819	
Avg. Reservoir Content	16,239	14,917	13,641	13,032	13,603	15,220	17,200	18,660	19,290	19,242	18,490	17,408	
Head	161	154	148	145	148	156	165	172	175	175	171	166	
GWh/mcm	0.385	0.370	0.356	0.349	0.355	0.373	0.396	0.412	0.419	0.419	0.410	0.398	
MW	999	918	839	802	837	937	1,058	1,148	1,187	1,184	1,138	1,071	
GWh	654	629	573	244	142	149	158	165	168	503	616	641	4,643
													2,700
Kurpsai													
Inflow mcm	1,700	1,700	1,611	700	400	400	400	400	400	1,200	1,500	1,611	12,022
GWh/mcm	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	
MW	800	800	800	800	800	800	800	800	800	800	800	800	
GWh	376	376	356	155	88	88	88	88	88	265	332	356	2,657
Tributary Inflow mcm	50	45	71	181	262	211	131	76	55	52	52	44	1,230
Tashumyr													
Inflow mcm	1,750	1,745	1,682	881	662	611	531	476	455	1,252	1,552	1,655	13,252
GWh/mcm	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	
MW	450	450	450	450	450	450	450	450	450	450	450	450	
GWh	222	222	214	112	84	78	67	60	58	159	197	210	1,683
Shamaldysai													
Inflow mcm	1,750	1,745	1,682	881	662	611	531	476	455	1,252	1,552	1,655	13,252
GWh/mcm	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	
MW	240	240	240	240	240	240	240	240	240	240	240	240	
GWh	109	108	104	55	41	38	33	30	28	78	96	103	822
Uch Kurgan													
Inflow mcm	1,750	1,745	1,682	881	662	611	531	476	455	1,252	1,552	1,655	13,252
GWh/mcm	0.070	0.070	0.070	0.070	0.070	0.070	0.070	0.070	0.070	0.070	0.070	0.070	
MW	180	180	180	180	180	180	180	180	180	180	180	180	
GWh	123	122	118	62	46	43	37	33	32	88	109	116	928
Total Hydro GWh	1,483	1,457	1,365	627	402	396	384	377	374	1,092	1,349	1,426	10,732
Total Hydro Capacity MW	2,669	2,588	2,509	2,472	2,507	2,607	2,728	2,818	2,857	2,854	2,808	2,741	15,989
2005 Energy Balance													0
KYG Energy Demand	1,688	1,629	1,389	759	605	574	581	570	552	1,040	1,377	1,719	12,484
Hydro Surplus	0	0	0	0	0	0	0	0	0	52	0	0	0
Energy Deficit	205	172	25	132	203	178	197	193	178	0	28	293	1,804
Supplied by Fuel Imports	205	172	25	132	203	178	197	193	178	0	28	250	1,760
Supplied by Energy Imports	0	0	0	0	0	0	0	0	0	0	0	43	43
Annual Deficit													1,804
2005 Capacity Balance													723
KYG Peak Demand 2005 MW	2,890	2,789	2,719	1,599	1,276	1,209	1,225	1,201	1,163	2,036	2,515	2,944	
Surplus Capacity	-221	-202	-210	873	1,231	1,397	1,504	1,618	1,694	818	293	-203	

ANNEX D: Toktogul Operating Regime T 55 (Summer 55%, 6,500 men)

	J	F	M	A	M	J	J	A	S	O	N	D
Toktogul												
Inflow mcm	401	355	405	688	1554	2480	2280	1439	790	684	512	434
Outflow mcm	855	1005	1055	900	1000	1300	1400	1300	600	698	905	1004
Reservoir BOM	18,503	18,049	17,399	16,749	16,537	17,091	18,271	19,151	19,290	19,400	19,386	18,993
Reservoir EOM	18,049	17,399	16,749	16,537	17,091	18,271	19,151	19,290	19,400	19,386	18,993	18,423
Avg. Reservoir Content	18,276	17,724	17,074	16,643	16,814	17,681	18,711	19,221	19,345	19,393	19,190	18,708
Head	170	168	165	163	163	167	172	175	175	175	175	172
Gwh/mcm	0.408	0.402	0.394	0.390	0.391	0.401	0.413	0.419	0.420	0.421	0.418	0.413
MW	1125	1091	1051	1024	1035	1088	1151	1183	1190	1193	1181	1151
Gwh	349	404	416	351	391	522	578	544	252	294	379	415
												4,894
												6,500
Kurpsal												
Inflow mcm	855	1005	1055	900	1000	1300	1400	1300	600	698	905	1004
Gwh/mcm	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221
MW	800	800	800	800	800	800	800	800	800	800	800	800
Gwh	189	222	233	199	221	287	309	287	133	154	200	222
												2,657
Tributary Inflow mcm	50	45	71	181	262	211	131	76	55	52	52	44
												1,230
Tashkumyr												
Inflow mcm	905	1050	1126	1081	1262	1511	1531	1376	655	750	957	1048
Gwh/mcm	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127
MW	450	450	450	450	450	450	450	450	450	450	450	450
Gwh	115	133	143	137	160	192	194	175	83	95	122	133
												1,683
Shanaldysai												
Inflow mcm	905	1050	1126	1081	1262	1511	1531	1376	655	750	957	1048
Gwh/mcm	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062
MW	240	240	240	240	240	240	240	240	240	240	240	240
Gwh	56	65	70	67	78	94	95	85	41	47	59	65
												822
Uch Kurgan												
Inflow mcm	905	1050	1126	1081	1262	1511	1531	1376	655	750	957	1048
Gwh/mcm	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07
MW	180	180	180	180	180	180	180	180	180	180	180	180
Gwh	63	74	79	76	88	106	107	96	46	53	67	73
												928
Total Hydro Gwh	772	898	941	829	939	1200	1284	1188	554	642	826	908
Total Hydro Capacity	2795	2761	2721	2694	2705	2758	2821	2853	2860	2863	2851	2821
												Winter
												Summer
												5,995
2005 Energy Balance												
KYG Energy Demand	1,688	1,629	1,389	759	605	574	581	570	552	1,040	1,377	1,719
Hydro Surplus	0	0	0	71	334	626	703	618	3	0	0	0
Energy Deficit:	916	731	449	0	0	0	0	0	0	398	550	812
From Fuel Imports	250	250	250	0	0	0	0	0	0	250	250	250
From Energy Imports	666	481	199	0	0	0	0	0	0	148	300	562
Annual Deficit												1,501
												2,356
												0
2005 Capacity Balance												
KYG Peak Demand	2,890	2,789	2,719	1,599	1,276	1,209	1,225	1,201	1,163	2,036	2,515	2,944
Surplus/Deficit Capacity	-96	-29	2	1095	1429	1549	1597	1652	1698	827	336	-123

ANNEX D: Toktogul Operating Regime T 65 (Summer 65%: 7,840 mcm)

	J	F	M	A	M	J	J	A	S	O	N	D	
Toktogul													
Inflow mcm	401	355	405	688	1554	2480	2280	1439	790	684	512	434	12022
Outflow mcm	771	660	660	1260	1360	1360	1300	1300	1260	660	660	771	12022
Reservoir BOM	18,500	18,130	17,825	17,570	16,998	17,192	18,312	19,292	19,431	19,400	19,424	19,276	
Reservoir EOM	18,130	17,825	17,570	16,998	17,192	18,312	19,292	19,431	19,500	19,424	19,276	18,939	
Avg. Reservoir Content	18,315	17,978	17,698	17,284	17,095	17,752	18,802	19,362	19,466	19,412	19,350	19,108	
Head	170	169	167	166	165	168	173	175	176	176	175	174	
Gwh/mcm	0.408	0.405	0.401	0.397	0.395	0.402	0.414	0.420	0.421	0.421	0.420	0.417	
MW	1127	1106	1089	1064	1052	1092	1157	1191	1198	1195	1191	1176	
Gwh	315	267	265	500	537	547	538	546	531	278	277	322	4923
													7840
Kurpsai													
Inflow mcm	771	660	660	1260	1360	1360	1300	1300	1260	660	660	771	12022
Gwh/mcm	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	
MW	800	800	800	800	800	800	800	800	800	800	800	800	
Gwh	170	146	146	278	301	301	287	287	278	146	146	170	2657
Tributary Inflow mcm	50	45	71	181	262	211	131	76	55	52	52	44	1230
Tashumyr													
Inflow mcm	821	705	731	1441	1622	1571	1431	1376	1315	712	712	815	13252
Gwh/mcm	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	
MW	450	450	450	450	450	450	450	450	450	450	450	450	
Gwh	104	90	93	183	206	200	182	175	167	90	90	104	1683
Shamaldysai													
Inflow mcm	821	705	731	1441	1622	1571	1431	1376	1315	712	712	815	13252
Gwh/mcm	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	
MW	240	240	240	240	240	240	240	240	240	240	240	240	
Gwh	51	44	45	89	101	97	89	85	82	44	44	51	822
Uch Kurgan													
Inflow mcm	821	705	731	1441	1622	1571	1431	1376	1315	712	712	815	13252
Gwh/mcm	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	
MW	180	180	180	180	180	180	180	180	180	180	180	180	
Gwh	57	49	51	101	114	110	100	96	92	50	50	57	928
Total Hydro Gwh	698	596	600	1152	1257	1254	1196	1190	1150	608	608	703	11012
Total Hydro Capacity	2797	2776	2759	2734	2722	2762	2827	2861	2868	2865	2861	2846	7200
2005 Energy Balance													
KYG Energy Demand	1,688	1,629	1,389	759	605	574	581	570	552	1,040	1,377	1,719	12,484
Hydro Surplus	0	0	0	393	652	680	615	620	598	0	0	0	3,559
Energy Deficit	990	1,034	789							432	769	1,016	5,031
From Fuel Imports	250	250	250							250	250	250	1,500
From Energy Imports	740	784	539							182	519	766	3,531
Annual Deficit													1,472
2005 Capacity Balance													
KYG Peak Demand 2005 MW	2,890	2,789	2,719	1,599	1,276	1,209	1,225	1,201	1,163	2,036	2,515	2,944	
Surplus/Deficit Capacity	-93	-13	40	1134	1446	1553	1602	1661	1705	828	346	-98	

ANNEX E: KAMBARATA #1 AND #2 WITH TOKTOGUL AND CASCADE

ALTERNATIVE A

TOKTOGUL REGIME T65 (7,840 BCM RELEASE APRIL TO SEPTEMBER)

K#1 RULE CURVE RW TO MAXIMIZE WINTER ENERGY

	J	F	M	A	M	J	J	A	S	O	N	D	
Kambarata #1													
Inflow mcm	324	342	379	673	1353	2201	1857	1256	711	523	458	384	10,463
Rule Curve	0.45	0.25	0.10	0.08	0.25	0.65	0.95	1.00	1.00	0.90	0.80	0.65	
Outflow mcm	1,224	1,242	1,054	763	588	401	507	1,031	711	973	908	1,059	10,463
Reservoir BOM	2,925	2,025	1,125	450	360	1,125	2,925	4,275	4,500	4,500	4,050	3,600	
Reservoir EOM	2,025	1,125	450	360	1,125	2,925	4,275	4,500	4,500	4,050	3,600	2,925	
Avg. Reservoir Content	2,475	1,575	788	405	743	2,025	3,600	4,388	4,500	4,275	3,825	3,263	
Avg. Head	185	155	124	107	122	171	216	232	233	230	221	208	
Gwh/mcm	0.445	0.371	0.296	0.256	0.291	0.410	0.517	0.555	0.560	0.550	0.529	0.497	
MW	953	796	635	548	625	878	1108	1190	1200	1180	1134	1067	
Gwh	544	461	312	195	171	164	262	572	398	536	480	527	4,624
Full gate Gwh	696	581	463	400	456	641	809	869	876	861	828	779	
Plant factor %	78	79	67	49	38	26	32	66	45	62	58	68	
Kambarata #2													
Inflow	1,224	1,242	1,054	763	588	401	507	1,031	711	973	908	1,059	
Outflow	1224	1242	1054	763	588	401	507	1031	711	973	908	1059	
Gwh/mcm	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	
MW	600	600	600	600	600	600	600	600	600	600	600	600	
Gwh	147	149	127	92	71	48	61	124	85	117	109	127	1,256
Full Gate Output	438	438	438	438	438	438	438	438	438	438	438	438	
Plant Factor	34	34	29	21	16	11	14	28	19	27	25	29	
Tributary Inflow mcm													
	77	13	26	15	191	289	423	183	79	161	54	50	1,560
Toktogul													
Inflow mcm	1301	1255	1080	778	779	690	930	1214	790	1134	962	1109	12,022
Outflow mcm	660	660	771	1260	1360	1360	1300	1300	1260	660	660	771	12,022
Reservoir BOM	18,000	18,641	19,236	19,545	19,063	18,482	17,812	17,442	17,356	19,000	19,474	19,000	
Reservoir EOM	18,641	19,236	19,545	19,063	18,482	17,812	17,442	17,356	16,886	19,474	19,400	19,338	
Avg. Reservoir Content	18,321	18,939	19,391	19,304	18,773	18,147	17,627	17,399	17,121	19,237	19,437	19,169	
Head	170	173	175	175	173	170	167	166	165	175	176	174	
Gwh/mcm	0.409	0.415	0.421	0.420	0.414	0.407	0.401	0.398	0.395	0.419	0.421	0.418	
MW	1127	1165	1193	1188	1155	1117	1085	1071	1054	1184	1196	1180	
Gwh	270	274	324	529	563	553	521	518	498	276	278	322	4,925
Plant Factor	33	32	37	61	67	68	66	66	65	32	32	37	
Summer													7,840
Kurpsai													
Inflow mcm	660	660	771	1260	1360	1360	1300	1300	1260	660	660	771	12,022
Gwh/mcm	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	
MW	800	800	800	800	800	800	800	800	800	800	800	800	
Gwh	146	146	170	278	301	301	287	287	278	146	146	170	2,657
Tributary Inflow mcm													
	50	45	71	181	262	211	131	76	55	52	52	44	1,230
Tashkumyr													
Inflow mcm	710	705	842	1441	1622	1571	1431	1376	1315	712	712	815	13,252
Gwh/mcm	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	
MW	450	450	450	450	450	450	450	450	450	450	450	450	
Gwh	90	90	107	183	206	200	182	175	167	90	90	104	1,683
Shamaldysai													
Inflow mcm	710	705	842	1441	1622	1571	1431	1376	1315	712	712	815	13,252
Gwh/mcm	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	
MW	240	240	240	240	240	240	240	240	240	240	240	240	
Gwh	44	44	52	89	101	97	89	85	82	44	44	51	822
Uch Kurgan													
Inflow mcm	710	705	842	1441	1622	1571	1431	1376	1315	712	712	815	13,252
Gwh/mcm	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	
MW	180	180	180	180	180	180	180	180	180	180	180	180	
Gwh	50	49	59	101	114	110	100	96	92	50	50	57	928
Cascade Hydro													
Inflow mcm	599	603	713	1,180	1,283	1,260	1,179	1,161	1,117	607	608	704	11,014
Total Hydro GWh	1,291	1,213	1,151	1,467	1,525	1,473	1,502	1,857	1,600	1,259	1,197	1,358	16,893
Hydro Capacity MW	4,351	4,232	4,098	4,006	4,050	4,265	4,463	4,531	4,523	4,634	4,600	4,516	

SUMMARY ALTERNATIVE A: T65/RW

	J	F	M	A	M	J	J	A	S	O	N	D	TOTALS		
													ANNUAL	WINTER	SUMMER
Total Hydro GWh	1,291	1,213	1,151	1,467	1,525	1,473	1,502	1,857	1,600	1,259	1,197	1,358	16,893	7,469	9,424
Hydro Capacity MW	4,351	4,232	4,098	4,006	4,050	4,265	4,463	4,531	4,523	4,634	4,600	4,516			
2010 Energy Balance															
KYG Energy Demand	1,485	1,485	1,315	1,055	768	742	742	742	755	1,146	1,302	1,485	13,024	8,218	4,806
Hydro Surplus	0	0	0	412	757	731	760	1,115	845	113	0	0	4,731	113	4,618
Thermal Deficit	194	272	164	0	0	0	0	0	0	0	105	127	862	862	0
Supplied by Fuel Imports	194	250	164							0	105	127	840	840	0
Supplied by Energy Impt	0	22	0								0	0	22	22	0
Annual Energy Surplus													3,869		0
2010 Capacity Balance															
KYG Peak Demand	3,129	3,129	2,772	2,628	1,914	1,849	1,849	1,849	1,881	2,415	2,745	3,129			
Surplus Capacity	1,221	1,102	1,326	1,379	2,136	2,416	2,614	2,682	2,642	2,218	1,855	1,387			
2015 Energy Balance															
KYG Energy Demand	1,584	1,584	1,403	1,125	820	792	792	792	806	1,223	1,389	1,584	13,893	8,766	5,127
Hydro Surplus	0	0	0	342	706	681	710	1,065	794	36	0	0	4,334	36	4,298
Thermal Deficit	293	371	252	0	0	0	0	0	0	0	192	226	1,334	1,334	0
Supplied by Fuel Imports	250	250	250							0	192	226	1,168	1,168	0
Supplied by Energy Impt	43	121	2							0	0	0	166	166	0
Annual Energy Surplus													3,000	3,000	0
2015 Capacity Balance															
KYG Peak Demand MW	3,338	3,338	2,957	2,372	1,727	1,669	1,669	1,669	1,698	2,577	2,928	3,338			
Surplus Capacity	1,013	894	1,141	1,635	2,323	2,596	2,794	2,862	2,825	2,057	1,672	1,178			

ANNEX E: KAMBARATA #1 AND #2 WITH TOKTOGUL AND CASCADE

ALTERNATIVE B

TOKTOGUL REGIME T65 (7,840 BCM RELEASE, APRIL TO SEPTEMBER)
K1 RULE CURVE RA TO MAXIMIZE ANNUAL ENERGY

	J	F	M	A	M	J	J	A	S	O	N	D	Totals
Kambarata #1													
Inflow mcm	324	342	379	673	1,353	2,201	1,857	1,256	711	523	458	384	10463
Rule Curve	0.94	0.91	0.89	0.90	0.90	0.90	1.00	1.00	1.00	1.00	0.99	0.97	
Outflow mcm	459	477	469	628	1,353	2,201	1,407	1,256	711	523	503	474	10463
Reservoir BOM	4,365	4,230	4,095	4,005	4,050	4,050	4,050	4,500	4,500	4,500	4,500	4,455	
Reservoir EOM	4,230	4,095	4,005	4,050	4,050	4,050	4,500	4,500	4,500	4,500	4,455	4,365	
Avg. Reservoir Content	4,298	4,163	4,050	4,028	4,050	4,050	4,275	4,500	4,500	4,500	4,478	4,410	
Avg Head	230	227	225	225	225	225	230	233	233	233	233	232	
Gwh/mcm	0.551	0.545	0.540	0.539	0.540	0.540	0.550	0.560	0.560	0.560	0.559	0.556	
MW	1,182	1,169	1,158	1,155	1,158	1,158	1,180	1,200	1,200	1,200	1,198	1,192	
Gwh	253	260	253	338	731	1,189	774	703	398	293	281	263	5,737
Full gate Gwh	863	853	845	843	845	845	861	876	876	876	874	870	
Plant factor %	29	30	30	40	86	141	90	80	45	33	32	30	
Kambarata #2													
Inflow	459	477	469	628	1,353	2,201	1,407	1,256	711	523	503	474	10,463
Outflow	459	477	469	628	1,353	2,201	1,407	1,256	711	523	503	474	
Gwh/mcm	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	
MW	600	600	600	600	600	600	600	600	600	600	600	600	
Gwh	55	57	56	75	162	264	169	151	85	63	60	57	1,256
Full Gate Output	438	438	438	438	438	438	438	438	438	438	438	438	
Plant Factor	13	13	13	17	37	60	39	34	19	14	14	13	
Tributary Inflow mcm	77	13	26	15	191	289	423	183	79	161	54	50	1,560
Toktogul													
Inflow mcm	536	490	495	643	1,544	2,490	1,830	1,439	790	684	557	524	12,022
Outflow mcm	660	660	771	1,260	1,360	1,360	1,300	1,300	1,260	771	660	660	12,022
Reservoir BOM	18,000	17,876	17,706	17,430	16,813	16,997	18,127	18,657	18,796	19,000	18,913	19,000	
Reservoir EOM	17,876	17,706	17,430	16,813	16,997	18,127	18,657	18,796	18,326	18,913	19,400	18,864	
Avg. Reservoir Content	17,938	17,791	17,568	17,122	16,905	17,562	18,392	18,727	18,561	18,957	19,157	18,932	
Head	169	168	167	165	164	167	171	172	172	173	174	173	
Gwh/mcm	0.404	0.403	0.400	0.395	0.393	0.400	0.409	0.413	0.411	0.416	0.418	0.415	
MW	1,104	1,095	1,081	1,054	1,040	1,081	1,132	1,152	1,142	1,167	1,179	1,165	
Gwh	267	266	308	498	534	544	532	537	518	321	276	274	4,874
Plant Factor	33	33	39	65	70	69	64	64	62	38	32	32	
Summer													7,840
Kurpsai													
Inflow mcm	660	660	771	1,260	1,360	1,360	1,300	1,300	1,260	771	660	660	12,022
Gwh/mcm	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	
MW	800	800	800	800	800	800	800	800	800	800	800	800	
Gwh	146	146	170	278	301	301	287	287	278	170	146	146	2,657
Tributary Inflow mcm	50	45	71	181	262	211	131	76	55	52	52	44	1,230
Tashkumyr													
Inflow mcm	710	705	842	1,441	1,622	1,571	1,431	1,376	1,315	823	712	704	13,252
Gwh/mcm	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	
MW	450	450	450	450	450	450	450	450	450	450	450	450	
Gwh	90	90	107	183	206	200	182	175	167	105	90	89	1,683
Shamaldysai													
Inflow mcm	710	705	842	1,441	1,622	1,571	1,431	1,376	1,315	823	712	704	13,252
Gwh/mcm	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	
MW	240	240	240	240	240	240	240	240	240	240	240	240	
Gwh	44	44	52	89	101	97	89	85	82	51	44	44	822
Uch Kurgan													
Inflow mcm	710	705	842	1,441	1,622	1,571	1,431	1,376	1,315	823	712	704	13,252
Gwh/mcm	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	
MW	180	180	180	180	180	180	180	180	180	180	180	180	
Gwh	50	49	59	101	114	110	100	96	92	58	50	49	928
Cascade Hydro	597	594	697	1,149	1,254	1,251	1,190	1,181	1,137	704	606	602	10,963
Total Hydro Gwh	905	911	1,007	1,563	2,148	2,704	2,133	2,034	1,621	1,060	948	923	17,956
Hydro Capacity	4,556	4,534	4,509	4,479	4,468	4,508	4,582	4,622	4,612	4,636	4,647	4,627	

SUMMARY ALTERNATIVE B: T65/RA

	J	F	M	A	M	J	J	A	S	O	N	D	WINTER SUMMER		
Total Hydro Gwh	905	911	1,007	1,563	2,148	2,704	2,133	2,034	1,621	1,060	948	923	17,956	5,753	12,203
Peaking Capacity	4,556	4,534	4,509	4,479	4,468	4,508	4,582	4,622	4,612	4,636	4,647	4,627			
2010 Energy Balance															
KYG Energy Demand	1,485	1,485	1,315	1,055	768	742	742	742	755	1,146	1,302	1,485	13,024	8,218	4,806
Hydro Surplus	0	0	0	508	1,379	1,962	1,391	1,292	865	0	0	0	7,397	0	7,397
Thermal Deficit	580	573	309	0	0	0	0	0	0	86	355	562	2,465	2,465	0
Supplied by Fuel Import	250	250	250							59	250	250	1,309	1,309	0
Supplied by Energy Imp	330	323	59							27	105	312	1,156	1,156	0
Annual Surplus													4,932		
2010 Capacity Balance															
KYG Peak Demand MW	3,129	3,129	2,772	2,628	1,914	1,849	1,849	1,849	1,881	2,415	2,745	3,129			
Surplus Capacity	1,427	1,405	1,737	1,852	2,554	2,659	2,733	2,773	2,731	2,221	1,902	1,498			
2015 Energy Balance															
KYG Energy Demand	1,584	1,584	1,403	1,125	820	792	792	792	806	1,223	1,389	1,584	13,893	8,766	5,127
Hydro Surplus	0	0	0	438	1,328	1,912	1,341	1,242	815	0	0	0	7,077	0	7,077
Thermal Deficit	679	672	397	0	0	0	0	0	0	163	442	661	3,014	3,014	0
Supplied by Fuel Import	250	250	250							163	250	250	1,500	1,500	0
Supplied by Energy Imp	429	422	147							0	192	411	1,514	1,514	0
Annual Surplus													4,063		
2015 Capacity Balance															
KYG Peak Demand MW	3,338	3,338	2,957	2,372	1,727	1,669	1,669	1,669	1,698	2,577	2,928	3,338			
Surplus Capacity	1,218	1,196	1,552	2,107	2,741	2,840	2,913	2,953	2,914	2,060	1,719	1,289			

ANNEX E:KAMBARATA #1 AND #2 WITH TOKTOGUL AND CASCADE

ALTERNATIVE C

**TOKTOGUL REGIME T55 (6,500 BCM RELEASE, APRIL TO SEPTEMBER)
K#1 RULE CURVE RW TO MAXIMIZE WINTER ENERGY**

	J	F	M	A	M	J	J	A	S	O	N	D	
Kambarata #1													
Inflow mcm	324	342	379	673	1353	2201	1857	1256	711	523	458	384	10,463
Rule Curve	0.45	0.25	0.10	0.08	0.25	0.65	0.95	1.00	1.00	0.90	0.80	0.65	
Outflow mcm	1,224	1,242	1,054	763	588	401	507	1,031	711	973	908	1,059	10,463
Reservoir BOM	2,925	2,025	1,125	450	360	1,125	2,925	4,275	4,500	4,500	4,050	3,600	
Reservoir EOM	2,025	1,125	450	360	1,125	2,925	4,275	4,500	4,500	4,050	3,600	2,925	
Avg. Reservoir Content	2,475	1,575	788	405	743	2,025	3,600	4,388	4,500	4,275	3,825	3,263	
Avg Head	185	155	124	107	122	171	216	232	233	230	221	208	
Gwh/mcm	0.445	0.371	0.296	0.256	0.291	0.410	0.517	0.555	0.560	0.550	0.529	0.497	
MW	953	796	635	548	625	878	1108	1190	1200	1180	1134	1067	
Gwh	544	461	312	195	171	164	262	572	398	536	480	527	4,624
Full gate Gwh	696	581	463	400	456	641	809	869	876	861	828	779	
Plant factor %	78	79	67	49	38	26	32	66	45	62	58	68	
Kambarata #2													
Inflow	1,224	1,242	1,054	763	588	401	507	1,031	711	973	908	1,059	
Outflow	1224	1242	1054	763	588	401	507	1031	711	973	908	1059	
Gwh/mcm	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	
MW	600	600	600	600	600	600	600	600	600	600	600	600	
Gwh	147	149	127	92	71	48	61	124	85	117	109	127	1,256
Full Gate Output	438	438	438	438	438	438	438	438	438	438	438	438	
Plant Factor	34	34	29	21	16	11	14	28	19	27	25	29	
Tributary Inflow mcm	77	13	26	15	191	289	423	183	79	161	54	50	1,560
Toktogul													
Inflow mcm	1301	1255	1080	778	779	690	930	1214	790	1134	962	1109	12,022
Outflow mcm	855	1005	1055	900	1000	1300	1400	1300	600	698	905	1004	12,022
Reservoir BOM	18,000	18,446	18,696	18,721	18,599	18,378	17,768	17,298	17,212	19,000	19,436	19,000	
Reservoir EOM	18,446	18,696	18,721	18,599	18,378	17,768	17,298	17,212	17,402	19,436	19,400	19,105	
Avg. Reservoir Content	18,223	18,571	18,709	18,660	18,489	18,073	17,533	17,255	17,307	19,218	19,418	19,053	
Head	170	172	172	172	171	169	167	165	166	175	176	174	
Gwh/mcm	0.407	0.411	0.413	0.412	0.410	0.406	0.400	0.396	0.397	0.419	0.421	0.417	
MW	1121	1143	1151	1148	1138	1112	1079	1062	1065	1183	1195	1172	
Gwh	348	413	436	371	410	527	559	515	238	292	381	418	4,911
Plant Factor	43	50	52	44	49	65	71	66	31	34	44	49	
										Summer			6,500
Kurpsai													
Inflow mcm	855	1005	1055	900	1000	1300	1400	1300	600	698	905	1004	12,022
Gwh/mcm	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	
MW	800	800	800	800	800	800	800	800	800	800	800	800	
Gwh	189	222	233	199	221	287	309	287	133	154	200	222	2,657
Tributary Inflow mcm	50	45	71	181	262	211	131	76	55	52	52	44	1,230
Tashkumyr													
Inflow mcm	905	1050	1126	1081	1262	1511	1531	1376	655	750	957	1048	13,252
Gwh/mcm	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	
MW	450	450	450	450	450	450	450	450	450	450	450	450	
Gwh	115	133	143	137	160	192	194	175	83	95	122	133	1,683
Shamaldysai													
Inflow mcm	905	1050	1126	1081	1262	1511	1531	1376	655	750	957	1048	13,252
Gwh/mcm	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	
MW	240	240	240	240	240	240	240	240	240	240	240	240	
Gwh	56	65	70	67	78	94	95	85	41	47	59	65	822
Uch Kurgan													
Inflow mcm	905	1050	1126	1081	1262	1511	1531	1376	655	750	957	1048	13,252
Gwh/mcm	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	
MW	180	180	180	180	180	180	180	180	180	180	180	180	
Gwh	63	74	79	76	88	106	107	96	46	53	67	73	928
Cascade Hydro	772	907	960	850	958	1,206	1,265	1,159	540	641	829	912	11,000
Total Hydro GWh	1,463	1,518	1,399	1,137	1,200	1,419	1,588	1,855	1,024	1,293	1,418	1,566	16,879
Hydro Capacity MW	4,345	4,209	4,056	3,967	4,033	4,260	4,457	4,522	4,535	4,632	4,599	4,509	

SUMMARY ALTERNATIVE C: T55/RW

	J	F	M	A	M	J	J	A	S	O	N	D	TOTALS		
													ANNUAL WINTER SUMMER		
Total Hydro GWh	1,463	1,518	1,399	1,137	1,200	1,419	1,588	1,855	1,024	1,293	1,418	1,566	16,879	8,656	8,223
Hydro Capacity MW	4,345	4,209	4,056	3,967	4,033	4,260	4,457	4,522	4,535	4,632	4,599	4,509			
2010 Energy Balance															
KYG Energy Demand	1,485	1,485	1,315	1,055	768	742	742	742	755	1,146	1,302	1,485	13,024	8,218	4,806
Hydro Surplus	0	33	84	82	432	676	846	1,113	269	147	116	81	3,679		
Thermal Deficit	22	0	0	0	0	0	0	0	0	0	0	0	22	22	0
Supplied by Fuel Imports	22	0	0	0								0	0	22	0
Supplied by Energy Imps	0	0	0	0								0	0	0	0
Annual Surplus													3,657		
2010 Capacity Balance															
KYG Peak Demand	3,129	3,129	2,772	2,628	1,914	1,849	1,849	1,849	1,881	2,415	2,745	3,129			
Surplus Capacity	1,215	1,080	1,284	1,339	2,119	2,411	2,608	2,673	2,653	2,217	1,854	1,380			
2015 Energy Balance															
KYG Energy Demand	1,584	1,584	1,403	1,125	820	792	792	792	806	1,223	1,389	1,584	13,893	8,766	5,127
Hydro Surplus	0	0	0	11	381	627	797	1,063	218	70	29	0	3,196		
Thermal Deficit	121	66	4	0	0	0	0	0	0	0	0	18	209	209	0
Supplied by Fuel Imports	121	66	4	0								0	0	209	0
Supplied by Energy Imps	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Surplus													2,986		
2015 Capacity Balance															
KYG Peak Demand MW	3,338	3,338	2,957	2,372	1,727	1,669	1,669	1,669	1,698	2,577	2,928	3,338			
Surplus Capacity	1,007	871	1,099	1,595	2,305	2,592	2,788	2,853	2,837	2,056	1,671	1,171			

ANNEX E:KAMBARATA #1 AND #2 WITH TOKTOGUL AND CASCADE

ALTERNATIVE D

TOKTOGUL REGIME T55 (6,500 BCM RELEASE, APRIL TO SEPTEMBER)
K#1 RULE CURVE RA TO MAXIMIZE ANNUAL ENERGY

	J	F	M	A	M	J	J	A	S	O	N	D	
Kambarata #1													
Inflow mcm	324	342	379	673	1353	2201	1857	1256	711	523	458	384	10,463
Rule Curve	0.94	0.91	0.89	0.90	0.90	0.90	1.00	1.00	1.00	1.00	0.99	0.97	
Outflow mcm	459	477	469	628	1,353	2,201	1,407	1,256	711	523	503	474	10,463
Reservoir BOM	4,365	4,230	4,095	4,005	4,050	4,050	4,050	4,500	4,500	4,500	4,500	4,455	
Reservoir EOM	4,230	4,095	4,005	4,050	4,050	4,050	4,500	4,500	4,500	4,500	4,455	4,365	
Avg. Reservoir Content	4,298	4,163	4,050	4,028	4,050	4,050	4,275	4,500	4,500	4,500	4,478	4,410	
Avg. Head	230	227	225	225	225	225	230	233	233	233	233	232	
Gwh/mcm	0.551	0.545	0.540	0.539	0.540	0.540	0.550	0.560	0.560	0.560	0.559	0.556	
MW	1182	1169	1158	1155	1158	1158	1180	1200	1200	1200	1198	1192	
Gwh	253	260	253	338	731	1189	774	703	398	293	281	263	5,737
Full gate Gwh	863	853	845	843	845	845	861	876	876	876	874	870	
Plant factor %	29	30	30	40	86	141	90	80	45	33	32	30	
Kambarata #2													
Inflow	459	477	469	628	1,353	2,201	1,407	1,256	711	523	503	474	
Outflow	459	477	469	628	1353	2201	1407	1256	711	523	503	474	
Gwh/mcm	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	
MW	600	600	600	600	600	600	600	600	600	600	600	600	
Gwh	55	57	56	75	162	264	169	151	85	63	60	57	1,256
Full Gate Output	438	438	438	438	438	438	438	438	438	438	438	438	
Plant Factor	13	13	13	17	37	60	39	34	19	14	14	13	
Tributary Inflow mcm	77	13	26	15	191	289	423	183	79	161	54	50	1,560
Toktogul													
Inflow mcm	536	490	495	643	1544	2490	1830	1439	790	684	557	524	12,022
Outflow mcm	905	905	1016	706	1250	1300	1300	1250	694	798	905	993	12,022
Reservoir BOM	18,000	17,631	17,216	16,695	16,632	16,926	18,116	18,646	18,835	19,000	18,886	19,000	
Reservoir EOM	17,631	17,216	16,695	16,632	16,926	18,116	18,646	18,835	18,931	18,886	19,400	18,531	
Avg. Reservoir Content	17,816	17,424	16,956	16,664	16,779	17,521	18,381	18,741	18,883	18,943	19,143	18,766	
Head	168	166	164	163	163	167	171	172	173	173	174	173	
Gwh/mcm	0.403	0.398	0.393	0.390	0.391	0.399	0.409	0.413	0.415	0.416	0.418	0.414	
MW	1096	1072	1043	1025	1033	1078	1131	1153	1162	1166	1178	1155	
Gwh	365	361	399	275	489	519	532	517	288	332	378	411	4,865
Plant Factor	46	46	52	37	65	66	64	61	34	39	44	49	
										Summer			6,500
Kurpsai													
Inflow mcm	905	905	1016	706	1250	1300	1300	1250	694	798	905	993	12,022
Gwh/mcm	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	0.221	
MW	800	800	800	800	800	800	800	800	800	800	800	800	
Gwh	200	200	225	156	276	287	287	276	153	176	200	219	2,657
Tributary Inflow mcm	50	45	71	181	262	211	131	76	55	52	52	44	1,230
Tashkumyr													
Inflow mcm	955	950	1087	887	1512	1511	1431	1326	749	850	957	1037	13,252
Gwh/mcm	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	0.127	
MW	450	450	450	450	450	450	450	450	450	450	450	450	
Gwh	121	121	138	113	192	192	182	168	95	108	122	132	1,683
Shamaldysai													
Inflow mcm	955	950	1087	887	1512	1511	1431	1326	749	850	957	1037	13,252
Gwh/mcm	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	
MW	240	240	240	240	240	240	240	240	240	240	240	240	
Gwh	59	59	67	55	94	94	89	82	46	53	59	64	822
Uch Kurgan													
Inflow mcm	955	950	1087	887	1512	1511	1431	1326	749	850	957	1037	13,252
Gwh/mcm	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	
MW	180	180	180	180	180	180	180	180	180	180	180	180	
Gwh	67	67	76	62	106	106	100	93	52	60	67	73	928
Cascade	812	807	905	661	1,157	1,198	1,190	1,136	635	728	826	899	10,954
Total Hydro GWh	1,120	1,124	1,215	1,075	2,050	2,651	2,133	1,990	1,119	1,084	1,167	1,219	17,946
Hydro Capacity MW	4,548	4,511	4,471	4,451	4,460	4,506	4,581	4,623	4,632	4,636	4,646	4,617	

SUMMARY ALTERNATIVE D: T55/RA

	J	F	M	A	M	J	J	A	S	O	N	D	TOTALS		
													ANNUAL	WINTER	SUMMER
Total Hydro GWh	1,120	1,124	1,215	1,075	2,050	2,651	2,133	1,990	1,119	1,084	1,167	1,219	17,946	6,929	11,017
Hydro Capacity MW	4,548	4,511	4,471	4,451	4,460	4,506	4,581	4,623	4,632	4,636	4,646	4,617			
2010 Energy Balance															
KYG Energy Demand	1,485	1,485	1,315	1,055	768	742	742	742	755	1,146	1,302	1,485	13,024	8,218	4,806
Hydro Surplus	0	0	0	20	1,281	1,909	1,391	1,247	363	0	0	0	6,191		
Thermal Deficit	365	361	100	0	0	0	0	0	0	62	135	266	1,289	1,289	0
Supplied by Fuel Imports	250	250	100							62	135	250	1,048	1,048	0
Supplied by Energy Imp	115	111	0	0	0	0	0	0	0	0	0	16	127	127	0
Annual Surplus													4,903		
2010 Capacity Balance															
KYG Peak Demand	3,129	3,129	2,772	2,628	1,914	1,849	1,849	1,849	1,881	2,415	2,745	3,129			
Surplus Capacity	1,419	1,382	1,699	1,823	2,546	2,657	2,732	2,774	2,750	2,220	1,901	1,488			
2015 Energy Balance															
KYG Energy Demand	1,584	1,584	1,403	1,125	820	792	792	792	806	1,223	1,389	1,584	13,893	8,766	5,127
Hydro Surplus	0	0	0	0	1,230	1,859	1,341	1,198	313	0	0	0	5,941		
Thermal Deficit	464	460	188	51	0	0	0	0	0	139	222	365	1,888	1,837	51
Supplied by Fuel Imports	250	250	188	170						139	222	250	1,469	1,299	170
Supplied by Energy Imp	214	210	0	0	0	0	0	0	0	0	0	115	538	538	0
Annual Surplus													4,053		
2015 Capacity Balance															
KYG Peak Demand MW	3,338	3,338	2,957	2,372	1,727	1,669	1,669	1,669	1,698	2,577	2,928	3,338			
Surplus Capacity	1,210	1,173	1,514	2,079	2,733	2,837	2,912	2,954	2,934	2,059	1,718	1,279			

ANNEX E: KAMBARATA # 2 WITHOUT KAMBARATA # 1

	J	F	M	A	M	J	J	A	S	O	N	D	Annual
Kambarata # 2													
Inflow	324	342	379	673	1353	2201	1857	1256	711	523	458	384	10,463
Outflow	324	342	379	673	1353	2201	1857	1256	711	523	458	384	
GWh/mcm	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	
MW	350	350	350	350	350	350	350	350	350	350	350	350	
GWh	39	41	46	81	162	264	223	151	85	63	55	46	1,256
Full Gate Output	256	256	256	256	256	256	256	256	256	256	256	256	
Plant Factor	15	16	18	32	64	103	87	59	33	25	22	18	

ANNEX F: KAMBARATA #1 ESTIMATE

Revised with data from Ertan					Harza 1993				
	Quantity	Unit	Unit Price (US\$)	Amount US\$	Explanation of Revision	Quantity	Unit	Unit Price (US\$)	Amount US\$
Preparatory Works	1	LS	35,000,000	35,000,000	Ertan Unit Lump Sum	1	LS	27,000,000	27,000,000
Diversion and Care of Water	1	LS	15,000,000	15,000,000	Ertan Unit Lump Sum*.7	1	LS		
Common Excavation	655,900	cu M	6.0	3,935,400	Ertan Unit Price	655,900	cu M	1.1	721,490
Open Rock Excavation	5,413,200	cu M	8.6	46,553,520	Ertan Unit Price	5,413,200	cu M	4.1	22,194,120
Underground Excavation	214,700	cu M	86.0	18,464,200	Ertan Unit Price	214,700	cu M	56.0	12,023,200
Shaft Excavation	23,500	cu M	60.0	1,410,000	Ertan Unit Price	23,500	cu M	77.0	1,809,500
Backfill	490,200	cu M	2.1	1,029,420	Ertan Unit Price	490,200	cu M	2.1	1,029,420
Powerhouse Concrete	163,800	cu M	87.0	14,250,600	Ertan Unit Price	163,800	cu M	100.0	16,380,000
Dam and Spillway Concrete	3,521,900	cu M	66.0	232,445,400	Ertan Unit Price	3,521,900	cu M	110.0	387,409,000
Other Reinforced Concrete	228,800	cu M	120.0	27,456,000	Ertan Unit Price	228,800	cu M	220.0	50,336,000
Underground Concrete	94,500	cu M	130.0	12,285,000	Ertan Unit Price	94,500	cu M	241.0	22,774,500
Grouting		LS	27,300,000	27,300,000	Harza Lump Sum	1	LS	27,300,000	27,300,000
Steel Liners	12,700	ton	3,360	42,672,000	Ertan Unit Price	12,700	ton	2,062	26,187,400
Structural Steel	10,400	ton	2,106	21,902,400	Harza Unit Price	10,400	ton	2,106	21,902,400
Rockbolts					Included in Excavation	1,156	ton	3,310	3,826,360
Turbine/Generator/Transformer	1,200	MW	120,000	144,000,000	Ertan Cost/MW	1,700	MW	220,000	374,000,000
Misc.Mechanical & Electoral	1	LS	16,000,000	16,000,000	Harza LS	1	LS	16,000,000	16,000,000
Gates,Cranes and Hoists	1	LS	37,000,000	37,000,000	Harza LS	1	LS	37,000,000	37,000,000
Switchyard	1	LS	12,000,000	12,000,000	Harza LS	1	LS	12,000,000	12,000,000
Substation	1	LS	20,000,000	20,000,000	Harza LS	1	LS	20,000,000	20,000,000
500 kv Transmission Line	260	km	400,000	104,000,000	Ertan \$/km	706	km	374,000	264,044,000
Base Cost				832,703,940					1,343,937,390
Contingencies	20% of Civil Works			99,940,788		25% of total			335,984,348
Engineering and Administration	7% of Total			65,285,131		10% of total			167,992,174
TOTAL				997,929,859					
In 2002 constant dollars(No change in MUV 1990 to 2000)				997,929,859					1,847,913,911
Add 20% (conditions less favorable than China)				1,197,515,830.75					

ANNEX F: KAMBARATA #2 ESTIMATE

Revised with data from Ertan					Harza 1993				
	Quantity	Unit	Unit Price (US\$)	Amount US\$	Explanation of Revision	Quantity	Unit	Unit Price (US\$)	Amount US\$
Preparatory Works	1 LS	1 LS	3,400,000	3,400,000	Harza Lump Sum	1 LS		3,400,000	3,400,000
Diversion and Care of Water	1 LS	1 LS	5,000,000	5,000,000	Estimate				
Common Excavation	538,000	cu M	6.0	3,228,000	Ertan Unit Price	538,000	cu M	1.1	591,800
Open Rock Excavation	12,300	cu M	8.6	105,780	Ertan Unit Price	12,300	cu M	4.1	50,430
Underground Excavation	215,300	cu M	86.0	18,515,800	Ertan Unit Price	215,300	cu M	56.0	12,056,800
Embankment	1,296,000	cu M	3.4	4,406,400	Harza Unit Price	1,296,000	cu M	3.4	4,406,400
Backfill	507,100	cu M	2.1	1,064,910	Ertan Unit Price	507,100	cu M	1.1	557,810
Powerhouse Concrete	198,900	cu M	87.0	17,304,300	Ertan Unit Price	198,900	cu M	150.0	29,835,000
Underground Concrete	94,500	cu M	130.0	12,285,000	Ertan Unit Price	157,800	cu M	230.0	36,294,000
Grouting	158,000	LS	38	6,004,000	Harza Unit Price	158,000	sq M	38	6,004,000
Steel Liners	5,510	ton	3,360	18,513,600	Ertan Unit Price	5,510	ton	2,062	11,361,620
Structural Steel	300	ton	2,106	631,800	Harza Unit Price	300	ton	2,106	631,800
Galvanized Steel	590	ton	3,000	1,770,000	Harza Unit Price	590	ton	3,000	1,770,000
Rockbolts	803		3,310	2,657,930	Harza Unit Price	803	ton	3,310	2,657,930
Turbine/Generator	400	MW	130,000	52,000,000	Ertan \$/MW				
Transformers	2	each	1,200,000	2,400,000		2	each	1,200,000	2,400,000
Generators						2	each	9,600,000	19,200,000
Misc. Mechanical	1 LS	1 LS	11,600,000	11,600,000	Harza Lump Sum	1 LS		11,600,000	11,600,000
Misc. Electrical	1 LS	1 LS	2,160,000	2,160,000	Harza Lump Sum	1 LS		2,160,000	2,160,000
Gates,Crates and Hoists	1 LS	1 LS	12,836,000	12,836,000	Harza Lump Sum	1 LS		12,836,000	12,836,000
Switchyard	1 LS	1 LS	6,000,000	6,000,000	Harza Lump Sum	1 LS		6,000,000	6,000,000
500 kv Transmission Line	47	km	374,000	17,578,000	Harza \$/km	47	km	374,000	17,578,000
Subtotal				199,461,520					181,391,590
Contingencies 20% of Civil Works				18,977,504		30% Civil Works and 20% of other items			51,807,000
Engineering and Administration 7% of Total				15,290,732		10% of total			25,536,000
TOTAL				233,729,756					258,734,590
In 2002 constant dollars(No change in MUW 1990 to 2000)				233,729,756					
Add 20% (conditions less favorable than China)				280,475,706.82					

Estimate for 600 MW

Additional Costs:			
Turbine/Generator	200 MW	130,000	26,000,000
Transformers	1 each	1,200,000	1,200,000
Misc. Mechanical	1 LS	5,000,000	5,000,000
Misc. Electrical	1 LS	1,000,000	1,000,000
Civil Works (in contingency & eng.)			10,000,000
Subtotal			43,200,000
TOTAL			333,675,706.82